

Compressor Station
HP Relief Header and Flare Evaluation

Revision A
December 2024



Table of Contents

Recommendation Summary	3
Study Description	3
Relief Header Design Criteria	4
Knockout Drum Design Criteria	4
Flare Design Criteria.....	5
Relief Header, Knock Drum and Flare Design Scenarios.....	6
Blocked Facility Outlet – 3 of 5 Compressors Running (C-1051, 1052 & 1057)	6
External Fire C-1051 and C-1052 (Fire Zone #1)	7
External Fire Sulfatreat Vessels (Fire Zone #2)	9
External Fire Closed Drain Tank Area (Fire Zone #3)	10
APPENDIX A – Relief Header Network Drawing.....	12
APPENDIX B – Knockout Drum (PV-111) and Flare (FL-1901).....	18
APPENDIX C – Blocked Facility Outlet Scenario Details	29
APPENDIX D – Fire Zone #1 – C-1051 & C-1052 Details.....	47
APPENDIX E – Fire Zone #2 – Sulfatreat Area Details	86
APPENDIX F – Fire Zone #3 – Closed Drain Tank Area Details	107
APPENDIX G – Fire Zone Plot Plan.....	122

Recommendation Summary

1. A 12" detonation arrestor is present at the entrance to the flare stack. As the arrestor can potentially plug and compromise the ability of the relief valves to safely relieve it is recommended to remove the arrestor. Note that per API STD 521, stoichiometric mixtures of hydrocarbon and air can produce pressures on the order of 7 to 8 times absolute operating pressure in the event of an explosion which would be roughly 100 psig. The knockout drum has a MAWP of 150 psig, therefore no loss of containment would be expected even if an explosion/deflagration occurred.
2. For the blocked facility outlet case, the maximum droplet size that could pass through the knockout drum is predicted to be 723 microns which exceeds the 300 – 600 micron recommended range. As the blocked facility outlet scenario assumes that 3 out of 5 compressors fail to shutdown on 3rd stage discharge PAHH, this scenario is very unlikely. As such, it is recommended that Targa consider the risk associated with this result prior to any physical changes.

Study Description

The relief header and flare system was evaluated to determine adequacy for scenarios that resulted in multiple, simultaneous releases to the system as well as single, large releases. The relief loads were determined based on standards, API STD 521 and standard engineering practices. Based on a review of the facility, the scenarios under consideration are a blocked facility outlet and several external fire scenarios impacting multiple pieces of equipment. These scenarios were quantified with the basic assumptions below:

- The external fire relief scenarios and loads were evaluated per API STD 521 and the following assumptions:
 - Adequate drainage is not present resulting in the use of the 34,500 factor in the heat flux equation as opposed to 21,000.
 - The latent heat was based on vaporization of the first 5% of the liquid by mass with all sensible heat removed.
 - The liquid levels were generally based on LSHH set points or other conservative assumptions if a LSHH was not present.
 - Vapor expansion cases were conservatively evaluated based on the maximum expected operating pressure which was typically the PSHH set point.
 - Vapor expansion cases are much more transient than boiling liquid cases, however the peak expansion relief load from each source was assumed to occur simultaneously.

- The maximum extent of an external fire is 5,000 ft² which was applied as a 80' diameter fire circle.
- The blocked outlet loads from the compressors were based on the mechanical characteristics of the compressor with minimum clearance and maximum suction pressure (PSHH set point). The compressors were assumed to relieve from the 3rd stage.

Relief Header Design Criteria

The primary constraint for the relief header piping is that developed back pressures in the header during these scenarios do not result in adverse operation or impact on capacity of any of the relief valves or blowdown valves involved in scenario. The back pressure profile for the relief header was determined based on a piping sketch that was developed by field walkdown (see Appendix A). A hydraulic model of the system predicated on a node and segment system was then prepared. The back pressure at each flowing device was determined and compared to established limits based on the type of device. Per the original flare specifications, the flare tip pressure drop is 0.82 psi @ 28.4 MMSCFD. The flare tip pressure drop was conservatively set to 2 psig for all scenarios. In general, the back pressure limitations in terms of percentage of set pressure are as follows:

Conventional relief valves – 10% of set pressure for process cases, 21% of set pressure for fire cases

Bellows relief valves – 30% (vapor) or 17% (liquid) of set pressure above which capacity must be de-rated

Pilot-operated relief valves, control valves and blowdown valves - ~50% of inlet pressure (vapor) above which capacity must be de-rated for sub-critical flow

The relief header evaluation is based on the required relief loads. The individual relief valve tail pipes have already been evaluated based on the actual relief device capacity, and the calculations are documented in the individual relief device binders.

Knockout Drum Design Criteria

The primary constraints for the flare knockout drum are droplet separation and liquid retention which in both cases have the objective of eliminating liquid flow to the flare. Per API STD 521, "Long-term field experience has shown that the dropout velocity in the drum may be based on that necessary to separate droplets from 300 microns to 600 microns in diameter." Also per API STD 521, the liquid retention time (hold-up) "should be based on a release that lasts 20-30 minutes." The Flare Knockout Drum (V-1920) is 72" in diameter by 20' seam-to-seam and the inlet and outlet nozzles are separated by approximately 17'. The knockout drum is emptied by P-1941 which is controlled in an on/off fashion by LIT-1920 which is set to come on at 14% level and shut-off at 7% level. In addition, LIT-1920 has a high level alarm at 30%. As no scenarios with significant liquid flow to the knockout drum were identified, liquid retention is not an issue for the knockout drum.

The droplet separation efficiency was evaluated based on GPSA equations for horizontal separation equipment with no mesh pad. The terminal droplet velocity was equated to the gas velocity to determine the minimum droplet size that the Knockout Drum could separate. As there are no free liquids associated with any of the scenarios, a liquid density of 40.0 lb/ft³ was assumed and liquid retention time is not applicable. The stated droplet separation efficiencies are based on the drum being at 14% level (pump off set point) which was found to be the worst case as compared to the low level of 7% and high alarm level of 30%. The drawing and U1-A form for the Flare Knockout Drum are presented in Appendix B.

Flare Design Criteria

The exit velocity is dictated by the diameter of the flare and volumetric flow. The maximum tolerable exit velocity is dependent on the particular flare and possibly the gas composition. For a typical pipe flare, API STD 521 states, “Many pipe flares, assisted or unassisted, and air assisted flares have been in service for years with Mach numbers ranging from Mach 0.8 and higher.” As this statement indicates, there is not an exact limit on the flare exit velocity. Per the original flare design, the worst case design condition was based on 28.4 MMSCFD of 21.43 MW gas at -8° F that results in Mach 0.25 and 0.82 psi pressure drop at the tip exit. Note that the scenario resulting in this original design basis is not known. This design case was used to calibrate the fraction heat radiated factor (F) with the closest match found to be at F = 0.16. Note that F = 0.3 is often quoted as a conservative default value.

The height of the flare is dictated by ensuring acceptable radiation levels at grade which is also somewhat subjective. The following table from API STD 521 provides some guidance on the time to reach the threshold of pain at differing radiation levels. Note that these values are based on direct skin exposure.

Radiation Level (Btu/ft ² /hr)	Time to Pain Threshold (seconds)
550	60
740	40
920	30
1500	16
2200	9
3000	6
3700	4
6300	2

1,500 Btu/hr/ft² is often quoted as a maximum radiation limit and is described as the maximum radiant heat intensity in areas where emergency actions lasting 2 to 3 minutes can occur with appropriate clothing. In this case, where egress from the area is the only objective, relatively higher radiation levels are more tolerable. Per the vendor specifications, the maximum radiation at grade is 1,200 Btu/ft²/hr for the aforementioned design case excluding solar radiation which is typically a maximum of 300 Btu/ft²/hr.

The Flare (FL-1901) is a Flare King Model EKVAP-H100-R22S-EPTKA which has a 14” Flare King utility flare tip, 44 BHP Blower and overall height of 100’. The original specification sheet and flare drawing are presented in Appendix B. Flare radiation profiles were quantified using the Brzustowski and Sommer methodology as outlined in API STD 521. The table below summarizes the four scenarios that were evaluated.

Scenario	Mass Flow (lb/hr)	MW	Temp. (F)	Tip Exit Mach No.	Max Rad. (Btu/hr/ft ²)	Max. KO Droplet Size
Blocked Facility Outlet	189,329	21.8	194	0.88	2,200	723
Fire Zone #1 – C-1051 & 1052	38,319	49.7	499	0.14	700	147
Fire Zone #2 – Sulfatreat Area	75,560	21.8	152	0.34	1,100	317
Fire Zone #3 – Closed Drain Tank Area	213,432	73.1	352	0.60	2,600	463

Relief Header, Knock Drum and Flare Design Scenarios

Based on the detailed review of all the individual relief devices along with other sources that feed the relief header and flare system, the following scenarios were selected for evaluation. The relief load calculations are included in the Appendices and more details on the relief valves can be found in the individual relief valve documentation binders.

Blocked Facility Outlet – 3 of 5 Compressors Running (C-1051, 1052 & 1057)

In the event that the facility outlet is blocked, the compressor discharge pressure and pressure through the high pressure gas equipment will increase. In the event that the compressors do not shut down on 3rd stage discharge PAHH, overpressure could occur with each compressor 3rd stage relief valve discharging at its required relief rate. The analysis was based on 3 of the 5 compressors (C-1051, C-1052 and C-1057) not shutting down which given a typical probability of failure on demand (PFOD) of 10% for pressure transmitters makes this scenario unlikely (0.5% chance) but conservative. As described above, the relief loads for the 3rd stage discharge PSVs were based on the mechanical characteristics of the compressor, minimum clearances and suction pressure at the 2nd stage discharge PSHH set point. The relief loads are therefore conservative.

Detailed relief load, relief header hydraulic, knockout drum separation, flare exit velocity and flare radiation calculations are detailed in Appendix C. The relief load and fluid properties are summarized in the table below.

PSV Tag	Eq. Tag	Eq. Description	Fire Load (MMSCFD)	Relief P (psig)	Relief T (F)	Relief MW
PSV-1051A	V-9432 (C-1051)	C-1051 3 rd Stage Discharge	19.65	1,584	260	21.8
PSV-1052A	V-9432 (C-1052)	C-1052 3 rd Stage Discharge	19.65	1,584	260	21.8
PSV-1057A	V-9432 (C-1057)	C-1057 3 rd Stage Discharge	10.11	1,584	270	21.8

Hydraulic Results

The table below summarizes the hydraulic results for the Blocked Facility Outlet Scenario.

Tag	Drawing	Device Size	Device Type	Set P (psig)	Back P (psig)	Back P (% set)
PSV-1051A	D-2415-F03C	2H3	Conventional	1,440	93.7	6.5
PSV-1052A	D-2415-F04C	2H3	Conventional	1,440	93.7	6.5
PSV-1057A	D-2415-F09C	2F3	Conventional	1,440	44.1	3.1

The back pressures are all below 10% of set pressure and, therefore, acceptable.

Knockout Drum Results

The knockout drum is capable of separating droplets greater than 723 microns based on the total flow of 79.1 MMSCFD and conditions of 6.8 psig and 195° F. This is slightly above the API STD 521 recommended range of 300 to 600 microns. Given the very low probability of this scenario as described above Targa should consider accepting this result.

Flare Results

The exit velocity from the flare tip is 0.88 Mach and the maximum radiation at grade is 2,200 Btu/hr/ft² at approximately 151' from the base of the flare stack. As the flare is located in a relatively remote location and the only requirement is for personnel to be able to escape the area, the radiation levels are acceptable.

External Fire C-1051 and C-1052 (Fire Zone #1)

Per API RP 521, an area of between 2,500 ft² and 5,000 ft² should be considered when determining the potential for multiple relief valves to relieve in the event of an external fire. C-1051 through C-1054 have roughly the same spacing with any two adjacent compressors potentially being in the same fire zone. As C-1051 and C-1052 are hydraulically furthest from the flare, the equipment and relief devices associated with these two compressors were selected for analysis. The new relief valves associated with the 1st Stage Suction Scrubbers were included with an estimated routing of 3" discharge piping to the 8" subheader. The fire relief load associated with the 3rd stage discharge is based on vapor expansion as compared to the other relief loads that are based on vaporization of hydrocarbon liquids. Finally, it has been recommended to replace PSV-1051C with a 4P6 modulating pilot relief valve, but this change will not impact the piping or this evaluation. A plot plan identifying all the fire zones is presented in Appendix G.

Detailed relief load, relief header hydraulic, knockout drum separation, flare exit velocity and flare radiation calculations are detailed in Appendix D. The loads and fluid properties are summarized in the table below.

PSV Tag	Eq. Tag	Eq. Description	Fire Load (lb/hr)	Relief P (psig)	Relief T (F)	Relief MW
PSV-1051 (New)	V-9410	C-1051 1 st Suction Scrubber	8,910	326.7	497.3	89.3
PSV-1051A	V-9432	C-1051 3 rd Discharge Bottle	1,428	1,742.4	435.0	21.8
PSV-1051B	V-9430	C-1051 3 rd Suction Scrubber	4,628	780.5	284.0	34.9
PSV-1051C	V-9420	C-1051 2 nd Suction Scrubber	3,870	302.5	377.3	56.6
PSV-1051E	F-3052	C-1051 Fuel Gas Filter	323.7	302.5	377.3	56.6
PSV-1052 (New)	V-9410	C-1052 1 st Suction Scrubber	8,910	326.7	497.3	89.3
PSV-1052A	V-9432	C-1052 3 rd Discharge Bottle	1,428	1,742.4	435.0	21.8
PSV-1052B	V-9430	C-1052 3 rd Suction Scrubber	4,628	780.5	284.0	34.9
PSV-1052C	V-9420	C-1052 2 nd Suction Scrubber	3,870	302.5	377.3	56.6
PSV-1052E	F-3052	C-1052 Fuel Gas Filter	323.7	302.5	377.3	56.6

Hydraulic Results

The table below summarizes the hydraulic results for the Fire Zone #1 Scenario.

Tag	Drawing	Device Size	Device Type	Set P (psig)	Back P (psig)	Back P (% set)
PSV-1051 (New)	D-2415-F03A	2J3	Pilot Operated	270	7.0	2.6
PSV-1051A	D-2415-F03C	2F3	Conventional	1,440	4.6	0.3
PSV-1051B	D-2415-F03B	3K4	Conventional	645	4.8	0.7
PSV-1051C	D-2415-F03A	4M6	Conventional	250	4.6	1.8
PSV-1051E	D-2415-F03F	1E1	Conventional	175	6.5	3.7
PSV-1052 (New)	D-2415-F04A	2J3	Pilot Operated	270	6.9	2.6
PSV-1052A	D-2415-F04C	2F3	Conventional	1,440	4.4	0.3
PSV-1052B	D-2415-F04B	3K4	Conventional	645	4.7	0.7
PSV-1052C	D-2415-F04A	4M6	Conventional	250	4.5	1.8
PSV-1052E	D-2415-F04F	1E1	Conventional	175	6.5	3.7

The back pressures on all relief valves are well below 21% of set pressure and, therefore, acceptable.

Knockout Drum Results

The knockout drum is capable of separating droplets greater than 147 microns based on the total flow of 7.0 MMSCFD and conditions of 2.2 psig and 499° F. This is below the API STD 521 recommended range of 300 to 600 microns and, therefore, acceptable.

Flare Results

The exit velocity from the flare tip is 0.14 Mach and the maximum radiation at grade is 700 Btu/hr/ft² at approximately 45' from the base of the flare stack. As the flare is located in a relatively remote location and the only requirement is for personnel to be able to escape the area, the radiation levels are acceptable.

External Fire Sulfatreat Vessels (Fire Zone #2)

Per API RP 521, an area of between 2,500 ft² and 5,000 ft² should be considered when determining the potential for multiple relief valves to relieve in the event of an external fire. All four Sulfatreat Vessels are within the same fire zone and were assumed to relieve at the peak vapor expansion rate simultaneously. A plot plan identifying all the fire zones is presented in Appendix G.

Detailed relief load, relief header hydraulic, knockout drum separation, flare exit velocity and flare radiation calculations are detailed in Appendix E. The loads and fluid properties are summarized in the table below.

PSV Tag	Eq. Tag	Eq. Description	Fire Load (lb/hr)	Relief P (psig)	Relief T (F)	Relief MW
PSV-1811	V-1811	Sulfatreat Vessel	18,890	1742.4	234.5	21.8
PSV-1812	V-1812	Sulfatreat Vessel	18,890	1742.4	234.5	21.8
PSV-1813	V-1813	Sulfatreat Vessel	18,890	1742.4	234.5	21.8
PSV-1814	V-1814	Sulfatreat Vessel	18,890	1742.4	234.5	21.8

Hydraulic Results

The table below summarizes the hydraulic results for Fire Zone #2 scenario.

Tag	Drawing	Device Size	Device Type	Set P (psig)	Back P (psig)	Back P (% set)
PSV-1811	D-2415-F14	1.5F2	Conventional	1,440	164.1	11.4
PSV-1812	D-2415-F14	1.5F2	Conventional	1,440	168.6	11.7
PSV-1813	D-2415-F14	1.5F2	Conventional	1,440	170.4	11.8
PSV-1814	D-2415-F14	1.5F2	Conventional	1,440	170.9	11.9

The back pressures on these conventional relief valves are below 21% of set pressure which is the limit for external fire scenarios and, therefore, acceptable.

Knockout Drum Results

The knockout drum is capable of separating droplets greater than 317 microns based on the total flow of 31.6 MMSCFD and conditions of 2.4 psig and 152° F. This is within the API STD 521 recommended range of 300 to 600 microns and, therefore, acceptable.

Flare Results

The exit velocity from the flare tip is 0.34 Mach and the maximum radiation at grade is 1,100 Btu/hr/ft² at approximately 135' from the base of the flare stack. As the flare is located in a relatively remote location and the only requirement is for personnel to be able to escape the area, the radiation levels are acceptable.

External Fire Closed Drain Tank Area (Fire Zone #3)

Per API RP 521, an area of between 2,500 ft² and 5,000 ft² should be considered when determining the potential for multiple relief valves to relieve in the event of an external fire. The Closed Drain Tank, and Condensate Flash are within the same fire zone. Note that the TEG Contactor and TEG Overhead Scrubber are also in this fire zone but relieve to atmosphere. It has been recommended to replace PSV-1912 with a 3" x 4" full-bore modulating pilot operated relief valve and PSV-1917 with a 2" x 3" full-bore modulating pilot operated relief valve, but these change will not impact the discharge piping or the analysis. A plot plan identifying all the fire zones is presented in Appendix G.

Detailed relief load, relief header hydraulic, knockout drum separation, flare exit velocity and flare radiation calculations are detailed in Appendix F. The loads and fluid properties are summarized in the table below.

PSV Tag	Eq. Tag	Eq. Description	Fire Load (lb/hr)	Relief P (psig)	Relief T (F)	Relief MW
PSV-1912	V-1912	Closed Drain Tank	130,705	302.5	385.6	72.5
PSV-1917	V-1917	Condensate Flash Tank	82,727	332.8	400.2	74.1

Hydraulic Results

The table below summarizes the hydraulic results for the Fire Zone #3 scenario.

Tag	Drawing	Device Size	Device Type	Set P (psig)	Back P (psig)	Back P (% set)
PSV-1912 ₁	D-2415-F23	3FB4	Pilot Operated	250	131.6	52.6
PSV-1917 ₁	D-2415-F24A	2FB3	Pilot Operated	275	147.0	53.5

₁ Relief valve size and type is based on proposed replacement relief valve. Current relief valves are undersized.

The back pressures on these pilot-operated relief valves are below the critical to subcritical transition ratio and, therefore, acceptable as no capacity de-rate is required.


Knockout Drum Results

The knockout drum is capable of separating droplets greater than 463 microns based on the total flow of 26.6 MMSCFD and conditions of 3.1 psig and 352° F. This is within the API STD 521 recommended range of 300 to 600 microns.

Flare Results

The exit velocity from the flare tip is 0.60 Mach and the maximum radiation at grade is 2,600 Btu/hr/ft² at approximately 147' from the base of the flare stack. As the flare is located in a relatively remote location and the only requirement is for personnel to be able to escape the area, the radiation levels are acceptable.

APPENDIX A – Relief Header Network Drawing




NON-DIMENSIONED LINES
ARE FITTING MAKE-UP
(NEGLECTIBLE LENGTH)

March 2024

REFERENCE DRAWINGS								
NO.	TITLE							



ENG. RECORD	DATE	TARGA WELLS VALLEY COMPRESSOR STATION RELIEF HEADER	
DRAWN BY RAK	10/2023	JOB NO.	23-1005
CHECKED		DRAWING NO.	SK-1001
APPROVED		Revision	A
APPROVED		REV.	A
SCALE			



NON-DIMENSIONED LINES
ARE FITTING MAKE-UP
(NEGLIGIBLE LENGTH)


March 2024

REFERENCE DRAWINGS								
NO.	TITLE							



ENG. RECORD	DATE	TARGA WELLS VALLEY COMPRESSOR STATION RELIEF HEADER	
DRAWN BY RAK	10/2023	JOB NO.	23-1005
CHECKED		DRAWING NO.	SK-1002
APPROVED		Revision A	REV. A
APPROVED			
SCALE			

ISSUED FOR 2023 RELIEF STUDY
NO. A
BY RAK
CHK
APVD
DATE 10/20/24



NO.	REFERENCE DRAWINGS		NO.	REVISION	BY	CHK	APVD	DATE
	TITLE							
			A	ISSUED FOR 2023 RELIEF STUDY	RAK			10/2023




ENG. RECORD	DATE
DRAWN BY RAK	10/2023
CHECKED	
APPROVED	
APPROVED	
SCALE	

TARGA WELLS VALLEY COMPRESSOR STATION RELIEF HEADER	
JOB NO.	23-1005
DRAWING NO.	SK-1003
REV.	A

March 2024

Revision A




NON-DIMENSIONED LINES
ARE FITTING MAKE-UP
(NEGLECTIBLE LENGTH)

March 2024

REFERENCE DRAWINGS							
NO.	TITLE						
		A	ISSUED FOR 2023 RELIEF STUDY	RAK	10/20	16	
		NO.	REVISION	BY	CHK	APVD	DATE



ENG. RECORD	DATE	TARGA WELLS VALLEY COMPRESSOR STATION RELIEF HEADER	
DRAWN BY RAK	10/2023	JOB NO.	23-1005
CHECKED		DRAWING NO.	SK-1004
APPROVED		Revision A	REV. A
APPROVED			
SCALE			



NON-DIMENSIONED LINES
ARE FITTING MAKE-UP
(NEGLIGIBLE LENGTH)

March 2024

REFERENCE DRAWINGS		NO.	TITLE
NO.	TITLE		
A	ISSUED FOR 2023 RELIEF STUDY	RAK	10/2023
NO.	REVISION	BY	CHK






ENG. RECORD	DATE	TARGA WELLS VALLEY COMPRESSOR STATION RELIEF HEADER
DRAWN BY RAK	10/2023	
CHECKED		JOB NO. 23-1005
APPROVED		DRAWING NO. SK-1005 Revision A
SCALE		REV. A

APPENDIX B – Knockout Drum (PV-111) and Flare (FL-1901)

HP Flare



V-1920



BILL OF MATERIALS		
NO.	DESCRIPTION	QTY
1	SA 516 Gr. 60	1.00
2	SA 516 Gr. 60	1.00
3	SA 516 Gr. 60	1.00
4	SA 516 Gr. 60	1.00
5	SA 516 Gr. 60	1.00
6	SA 516 Gr. 60	1.00
7	SA 516 Gr. 60	1.00
8	SA 516 Gr. 60	1.00
9	SA 516 Gr. 60	1.00
10	SA 516 Gr. 60	1.00
11	SA 516 Gr. 60	1.00
12	SA 516 Gr. 60	1.00
13	SA 516 Gr. 60	1.00
14	SA 516 Gr. 60	1.00
15	SA 516 Gr. 60	1.00
16	SA 516 Gr. 60	1.00
17	SA 516 Gr. 60	1.00

AFI # 7 2 0 0 3

KINDER MORGAN

CONSTRUCTION CORP.

NO.	DESCRIPTION	QTY	UNIT	REVISION
1	SA 516 Gr. 60	1.00	PLATE	1
2	SA 516 Gr. 60	1.00	PLATE	1
3	SA 516 Gr. 60	1.00	PLATE	1
4	SA 516 Gr. 60	1.00	PLATE	1
5	SA 516 Gr. 60	1.00	PLATE	1
6	SA 516 Gr. 60	1.00	PLATE	1
7	SA 516 Gr. 60	1.00	PLATE	1
8	SA 516 Gr. 60	1.00	PLATE	1
9	SA 516 Gr. 60	1.00	PLATE	1
10	SA 516 Gr. 60	1.00	PLATE	1
11	SA 516 Gr. 60	1.00	PLATE	1
12	SA 516 Gr. 60	1.00	PLATE	1
13	SA 516 Gr. 60	1.00	PLATE	1
14	SA 516 Gr. 60	1.00	PLATE	1
15	SA 516 Gr. 60	1.00	PLATE	1
16	SA 516 Gr. 60	1.00	PLATE	1
17	SA 516 Gr. 60	1.00	PLATE	1
18	SA 516 Gr. 60	1.00	PLATE	1
19	SA 516 Gr. 60	1.00	PLATE	1
20	SA 516 Gr. 60	1.00	PLATE	1

SPECIFICATIONS		
1	SA 516 Gr. 60	1.00
2	SA 516 Gr. 60	1.00
3	SA 516 Gr. 60	1.00
4	SA 516 Gr. 60	1.00
5	SA 516 Gr. 60	1.00
6	SA 516 Gr. 60	1.00
7	SA 516 Gr. 60	1.00
8	SA 516 Gr. 60	1.00
9	SA 516 Gr. 60	1.00
10	SA 516 Gr. 60	1.00
11	SA 516 Gr. 60	1.00
12	SA 516 Gr. 60	1.00
13	SA 516 Gr. 60	1.00
14	SA 516 Gr. 60	1.00
15	SA 516 Gr. 60	1.00
16	SA 516 Gr. 60	1.00
17	SA 516 Gr. 60	1.00
18	SA 516 Gr. 60	1.00
19	SA 516 Gr. 60	1.00
20	SA 516 Gr. 60	1.00

U-1920

FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
 (Alternate Form for Single Chamber, Completely Shop or Field Fabricated Vessels Only)
 As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division 1

1. Manufactured and certified by SouthTex Treaters, Inc. 13405 HWY. 191 ODESSA TX 79765 USA
 (Name and address of Manufacturer)

2. Manufactured for FRIO LaSalle Pipeline, LP 18615 Tuscany Stone, Suite 300 San Antonio Texas 78258 USA
 (Name and address of Purchaser)

3. Location of installation UNKNOWN
 (Name and address)

4. Type Horizontal 916 143901-156 702 2014
 (Horizontal or vertical, tank) (Manufacturer's serial number) (CRN) (Drawing number) (National Board number) (Year built)

5. ASME Code, Section VIII, Division 1 2013 Edition
 [Edition and Addenda, if applicable (date)] (Code Case numbers) [Special service per UG-120(d)]

6. Shell SA-516 70N 0.375" 0.0625" 72" O.D. 20'-0" S/S
 (Material spec number, grade) (Nominal thickness) (Corr. allow.) (Inner diameter) (Length (overall))

Body Flanges on Shells													
No.	Type	ID	OD	Flange Thk	Min Hub Thk	Material	How Attached	Location	Bolting				
									Num & Size	Bolting Material	Washer (OD, ID, thk)	Washer Material	
-	-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-	-

7. Seams TYPE 1 Full 100 TYPE 1 Spot 85 2
 [Long (welded, dbl., singl., lap, butt)] [R, T, (spot or full)] (Eff. %) (H T, temp.) (Time, hr) [Girth (welded, dbl., singl., lap, butt)] [R, T (spot (Eff. %) (No. of courses) or full)]

8. Heads: (a) Material SA-516 70N (b) Material SA-516 70N
 (Spec. no., grade) (Spec. no., grade)

Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side To Pressure (Convex or Concave)
(a) ENDS	0.3125"	0.0625"	-	-	2:1	-	-	-	CONCAVE
(b)	-	-	-	-	-	-	-	-	-

Body Flanges on Heads											
Location	Type	ID	OD	Flange Thk	Min Hub Thk	Material	How Attached	Num & Size	Bolting Material	Washer (OD, ID, thk)	Washer Material
(b)	-	-	-	-	-	-	-	-	-	-	-

9. MAWP 150 15 at max. temp. 300 300
 (Internal) (External) (Internal) (External)

Min. design metal temp. -20 at 150 Hydro., pneu., or comb. test pressure 195

Proof test _____

10. Nozzles, inspection, and safety valve openings

Purpose (Inlet, Outlet, Drain, etc.)	No.	Diameter or Size	Type	Material		Nozzle Thickness		Reinforcement Material	Attachment Details		Location (Insp Open.)
				Nozzle	Flange	Nom.	Corr.		Nozzle	Flange	
Manway	1	18"	RFLN	SA-105	-	1"	0.0625"	INHERENT	UW16.1c	-	HEAD
Inlet/Outlet	2	20"	RFLN	SA-105	-	1"	0.0625"	INHERENT	UW16.1c	-	SHELL
Drain	1	4"	RFLN	SA-105	-	0.750"	0.0625"	INHERENT	UW16.1c	-	SHELL
Bridle, TI, PI, Spare	5	2"	RFLN	SA-105	-	0.531"	0.0625"	INHERENT	UW16.1c	-	SHELL
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

11. Supports: Skirt NO Lugs 2 Legs 2 Other - Attached WELDED TO SHELL
 (Yes or no) (Number) (Number) (Describe) (Where and how)

12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report: ITEM #6. WAGNER PLATE WORKS, S/N 13-440-3B & 3C
 (Name of part, item number, Manufacturer's name and identifying stamp)

IMPACT EXEMPT PER UCS-66. UG-125 PRV PROVIDED BY USER

U1A - Revision 4 - FP 2014.7.0

FORM U-2A MANUFACTURER'S PARTIAL DATA REPORT (ALTERNATIVE FORM)
A Part of a Pressure Vessel Fabricated by One Manufacturer for Another Manufacturer
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured and certified by WAGNER PLATE WORKS, LLC, 4142 W. 49TH STREET, TULSA, OKLAHOMA 74107
(Name and address of Manufacturer)

2. Manufactured for KINDER MORGAN / SOUTHTEX TREATERS, 13405 HWY 1941, ODESSA, TX 76765
(Name and address of Purchaser)

3. Location of installation UNKNOWN
(Name and address)

4. Type: SHELL 13-440-3B & 3C NA
(Description of vessel part (shell, two-piece head, tube bundle)) (Mfg's serial No.) (CRN)

13-440-3 WPW 2013
(Nat'l. Bd. No.) (Drawing No.) (Drawing prepared by) (Year built)

5. ASME Code, Section VIII, Div. 1 2010 - 2011 - NA
Edition and Addenda (date) Code Case No. Special Service per UG-120(c)

6. Shell (a) No. of course(s): 1 EACH (b) Overall length (ft & in.): 10' - 0"

No	Course(s)		Material	Thickness		Long Joint (Cat. A)			Circum. Joint (Cat. A, B & C)			Heat Treatment		
	Diameter in.	Length ft & in.		Nom.	Corr.	Type	Full	Spot	None	Eff.	Full	Spot	None	Temp.
1	72" O.D.	10' - 0"	SA-516-70N	3/8"	-	1	FULL	100%	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-	-	-	-

7. Heads: (a) - (b) -

Location (Top, Bottom, Ends)	(Mat'l Spec. No., Grade or Type) H.T. - Time & Temp					(Mat'l Spec. No., Grade or Type) H.T. - Time & Temp								
	Thickness	Radius		Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Fiat Diameter	Side to Pressure		Category A				
(a)	Min	Corr	Crown	Knuckle	-	-	-	Convex	Concave	Type	Full	Spot	None	Eff.
(b)	-	-	-	-	-	-	-	-	-	-	-	-	-	-

If removable, bolts used (describe other fastening) -

8. MAWP - - psi at max. temp. - - °F Min. design metal temp. - - °F at - - psi
(internal) (external) (internal) (external)

9. Impact test NO at test temperature of - °F
(Indicate yes or no and the component(s) impact tested)

10. Hydro. ~~proof~~ ~~or~~ ~~burst~~ test press. BY CUSTOMER Proof test -

11. Nozzles, inspection, and safety valve openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	Diameter or Size	Flange Type	Material		Nozzle Thickness		Reinforcement Material	How Attached		Location (Insp. Open.)
				Nozzle	Flange	Nom.	Corr.		Nozzle	Flange	
-	-	-	-	-	-	-	-	-	-	-	-
-	-	-	-	-	-	-	-	-	-	-	-

12. Supports: Skirt NO Lugs - Legs - Others - Attached -
(Yes or No) (No.) (No.) (Describe) (Where and How)

13. Remarks WPW RETAINS RESPONSIBILITY FOR WORKMANSHIP AND MATERIAL ONLY. COLD FORMED. HAS NOT BEEN P.W.H.T. DESIGN IS THE RESPONSIBILITY OF THE CUSTOMER. WPS QUALIFIED A.W. & P.W.H.T. P.O. 6500037-0-STAT

CERTIFICATE OF SHOP/FIELD COMPLIANCE

We certify that the statements made in this report are correct and that all details of material, construction, and workmanship of this pressure vessel part conform to the ASME Code for Pressure Vessels, Section VIII, Division 1.

U Certificate of Authorization No. 32.396 Expires 02/27/2016

Date 08/30/2013 Name WAGNER PLATE WORKS, LLC Signed Stephanie Eastin
(Manufacturer) (Representative)


CERTIFICATE OF SHOP/FIELD INSPECTION

I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and the State or Province of OKLAHOMA and employed by HSB CT of HARTFORD CT have inspected the pressure vessel part described in this Manufacturer's Data Report on 08/30/2013, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel part in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel part described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 08/30/2013 Signed [Signature] Commissions NB13413A OK 962
(Authorized Inspector) (Nat'l. Board incl. endorsement, State, Province and No.)

9E 702

CERTIFIED BY


SOUTHTEX
 TREATERS

ODESSA, TEXAS

MAWP	150	PSI	@	300	°F
MAEWP	15	PSI	@	300	°F
MDMT	-20	°F	@	150	PSI
S.N.	916		C.A.	0.0823	
TEST	193	PSI	YR	2014	

FLANGE X 200X 100T DRUM



72-00 X 20-0 S/S

ASME
 A
 RT-2

FL-1901

BILL OF MATERIALS

ITEM	QTY	WEIGHT (LBS)	STOCK NUMBER	DESCRIPTION	MATERIAL
1	1	147.9	BAF75516	PLATE 56" OD X 16 1/8" ID X 3/8" THK	SA-36
2	1	6.4	BAF1957	BAR FLAT 1/4" X 1/2" THK X 11 1/4" LG	A-36
3	12.0M	20.0	BAF2014	1/4" X 2" FLAT BAR	A-36
4	66	.5	BAF2014	BAR FLAT 2" X 1/4" THK X 3 3/8" LG	A-36
5	8	2.8	BAF2018	BAR FLAT 2" X 1/4" THK X 20" LG	A-36
6	36	.3	BAF2035	BAR FLAT 2" X 3/8" X 1 1/2" X .005	304 SS
7	11.38	45.2	BAF2035	3/8" X 10" FLAT BAR	A-36
8	1	147.9	BAF75516	PLATE 54" OD X 12" ID X 1/4" THK ROLLED/END	304 SS
9	1	3.4	BRT1001	FLARE NAME PLATE BRACKET	A-36
10	9	1.0	BRT1100	GUY WIRE LUG	A-36
11	3	3.0	BRT1110	WINCH BRACKET	A-36
12	3	.2	BRT1130	TAG LINE BRACKET	A-36
13	3	.9	BRT1200	REGULATOR BRACKET	A-36
14	3	2.4	BRT1210	PULLEY BOX	SA-36
15	15	.3	BRT1220	TRACK ALIGNMENT PIN	A-36
16	1	77.9	EL4585	1/2" STD SR 90	SA-224WB
17	3	4.5	EL4585	ELBOW 4" SCH 10 LR 90 DEG	304 SS
18	3	2.9	FLN3130	WINCH 2000#	304 SS
19	2	76.0	FLN4214	PLATE 42" OD X 36 1/8" ID X 3/4" THK 8 3/4" HOLES	SA-36
20	3	84.5	FLN4516	FLANGE 12" 150# RFWN	SA-1105
21	12	3.3	GNS4211	PIPE 2" SCH STD X 11 3/4" LG 1" SLOT	304 SS
22	3	1.8	GAUG4488	GAUGE PRESS 0-300#	304 SS
23	1	2.2	HARDWARE	COUPLING HALF 2" 3000#	SA-224 WB
24	2	.3	HARDWARE	CORPLNG 1/2" 3000#	SA-224 WB
25	2	22.1	LUG2002	CERTIFIED LIFTING LUGS	A-51
26	1	7126.7	PIPE1708	PIPE 36" X 50# STD X 598 3/4" LG	A-51
27	1	6780.0	PIPE1708	PIPE 36" X 50# STD X 569 5/8" LG	A-51
28	1	294.0	PIPE1708S	PIPE 36" X 50# STD X 24" LG 30KSS	304 SS
29	1	20.2	PIPE4391	PIPE 12" X 50# STD X 13 1/2" LG	A-51
30	1	2214.1	PIPE4391	PIPE 12" X 50# STD X 555 1/2" LG	A-51
31	1	2296.8	PIPE4391	PIPE 12" X 50# STD X 555 1/2" LG	A-51
32	1	102.1	PIPE4391S	PIPE 12" X 50# STD X 24" LG 30KSS	304 SS
33	1	103.8	PLAT1358	PLATE 35 1/4" OD X 3/8" THK	A-36
34	1	429.4	PLAT1410	PLATE 44" DIA X 1" THK X 8-1" HOLES ON 4" BC	A-36
35	3	1.6	REG12000	REGULATOR 300 BAR	A-36
36	3	34.8	BRT12012	REGULATOR PILOT TC SLED W/ 70 PILOT	SA-36
37	3	124.4	TBR1510	TUBING RECT 1 1/2" X 1 1/8" X 116 1/8" LG	SA-36
38	3	124.6	TBR1510	TUBING RECT 1 1/2" X 1 1/8" X 116 1/8" LG	SA-36



APPROVALS:
ENGINEERING: _____
PROD COORDINATOR: _____
PROD SUPER: _____
QUALITY CONTROL: _____

WEIGHT: 21298 lbmass

SCHEDULE OF OPENINGS

ITEM	DESCRIPTION	TYPE	RATING	SIZE	ORIENTATION	LENGTH	ANGLE	DIMS
A	INLET FLANGE	RFWN	150#	12"	0°	± 1/8"	± 1	<48"
B	STACK FLANGE	RFWN	36"	36"	0°	± 1/4"	± 1	>48"
C	TIP FLANGE	RFWN	36"	36"	0°	± 1/4"	± 1	>48"
D	DRAIN	NPT	3000#	1/2"	30°	± 1/4"	± 1	OVERALL
E	SITE GLASS	NPT	3000#	1/2"	30°	± 1/4"	± 1	OVERALL
F	TRACK	PILOT	THERMO	RETRACT	60° / 180° / 300°	± 1/4"	± 1	OVERALL
G	GUY WIRE	60#	AC76	AC76	90° / 270°	3-7	MBS	
H	BLOWER	60#	AC76	AC76	90° / 270°	3-7	MBS	
I	LIFTING LUGS	CERTIFIED	150#	12"	90° / 270°			
J	GAS STACK FLANGE (NOT SHOWN)	RFWN	150#	12"	90° / 270°			
K								

ITEMS NOT SHOWN

ITEM	QTY	PART NUMBER	DESCRIPTION	MATERIAL
1	1	BLK40000	GRD. ADP 36 BLOWER	
2	36	CLP10102	CABLE CLAMP 1/2"	
3	18	CLP10316	CABLE CLAMP 3/16"	
4	1	CLJAC280	BOX CONTROL 110V W/ THERMO	
5	1	FAD11215	12" DETONATION ARRESTOR	
6	3	FLN3130	WINCH EYE BLOCK	
7	3	GSET1125	12" FLANGE GASKET BRN	304 SS
8	1	HOS2550	57 STAINLESS STEEL FLEX HOSE	304 SS
9	1	HWEN1000	RSCC WIRE BRITLE (ENFIBED)	304 SS
10	18	THW1012	CABLE THIMBLE 1/2"	
11	2	THW1016	CABLE THIMBLE 3/16"	
12	660	WR1015	50 WIRE 16-3	
13	900	WR1015	7/16 SS CABLE	
14	858	WR1015	7/16 SS CABLE	


100" ANNULAR AIR ASSISTED TIP FLARE

DATE: _____
 DRAFTSMAN: _____
 CHECKED: _____
 DATE: 7/1/2014


Customer: _____
 Job #: FLD20978
 Location: _____

REVISION HISTORY

REV	INITIAL DESIGN	DESCRIPTION	ENG. APPROVAL DATE	AUTHOR
0				
1				
2				
3				
4				
5				
6				
7				
8				



FL-1901




ITEM	DESCRIPTION	MA
1	HEAT BAKING	MA
2	WIND BOWNET	MA
3	WIRE LOG	MA
4	WINCH 2000#	MA
5	DRAIN CONNECTION	SA
6	GASSE PRESS 2-2000#	SA 2
7	SIGHT GLASS PORT'S	SA 2
8	PIPE SIZE TBD	MA
9	TIP PIPE SEE QUOTE	MA
10	PIPE SIZE TBD	MA
11	PIPE SIZE TBD	MA
12	PIPE SIZE TBD	MA
13	BASE PLATE, SIZE AND HOLES TBD	MA
14	REGULATOR AS REQ	SA 2
15	REGULATOR AS REQ	SA 2
16	REGULATOR AS REQ	SA 2
17	RETRACTABLE PILOT TO SIZED TO PILOT	MA
18	PILOT TRACK	MA

ITEM	DESCRIPTION	WINDING OR SPANNING	TYPE	WINDING	ORIENTATION	LENGTH	ANGLE	DIMS
A	PIPE FLANGE	SEWAL	150#	SEE QUOTE	90	1.12	81	448
B	STACK FLANGE	SEWAL	150#	SEE QUOTE	90	1.14	21	348
C	TIP FLANGE	SEWAL	150#	SEE QUOTE	90	1.14	25	OVERALL
D	DRUM	SEWAL	150#	SEE QUOTE	90			
E	PIPE FLANGE	SEWAL	150#	SEE QUOTE	90			
F	TRACK	SEWAL	150#	SEE QUOTE	90			
G	PILOT TRACK	SEWAL	150#	SEE QUOTE	90			

DATE: 4/27/2011
DRAWN BY: J. THOR
CHECKED BY: J. THOR
1/27/2011

ENG APPROVAL DATE: _____
DESIGN APPROVAL DATE: _____



MESA
MESA GAS SERVICES GROUP, INC.

13201 W. 43rd Ave. Suite 100
Denver, CO 80231
TEL: (303) 293-2700
FAX: (303) 293-2700
www.mesagroup.com

CUSTOMER VISIT: _____
CUSTOMER JOB #: FL02000
DRAFTSMAN: J. THOR
DATE DRAWN: 10/18/2012
JOB CODE: _____

NOTE: THIS DOCUMENT CONTAINS PROPRIETARY INFORMATION AND IS TO BE KEPT SECURE. APPROVED FOR RELEASE SUBJECT TO THE TERMS AND CONDITIONS OF THE MESA GAS SERVICES GROUP, INC. FROM NATURAL GAS SUPPLIERS ONLY.

LARGE UTILITY TIP FLARE

Design Utility Tip Flare: **D FKUT-HXX-RXXS-EXXX**

FLARE KING, INC.

Customer: Kinder Morgan
Job: PRV

Date: 5/30/2014 10:42

DATA ENTRY SECTION:				CALCULATED DATA:			
Relief Fluid Data:		Mol %	Duty_(mmscfd): 28.400	Relief Fluid Data:			
H ₂ S	0.2504		Temp. °F -8	Total Flow	28.400 mmscfd		
N ₂	0.1869		Inlet Pres_{psi} 5	MW/SG:	21.43	0.740	
O ₂	0.0000		Pilot X	Density:	0.0565 lb/scf		
H ₂	0.0000		Sparker	LHV:	1148.9 btu/scf		
H ₂ O	0.0313		Retrackable X	LHV:	20321.1 btu/lb		
CO ₂	1.0562		Guyed X	k _(Cp/Cv)	1.271		
Methane - C ₁	76.8375		Free Standing	Z _{Compressibility}	0.9948		
Ethane - C ₂	12.7360		Solar	Viscosity	0.010 cp		
Propane - C ₃	5.3682		Enclosed	C:H _{ratio}	0.273		
isoButane - iC ₄	0.7464			Flow:	66827.1 lb/hr		
neoButane - nC ₄	1.5516			Duty:	1358.00 mmBTU/hr		
isoPentane - iC ₅	0.3940			Flow:	291.261 acfs		
neoPentane - nC ₅	0.4332			Air Req'd:	236248.1 scfm		
Hexane - C ₆	0.2960			Air Req'd(ft ³ air / ft ³ gas):	11.98		
Heptane - C ₇	0.0989			Flare Data:			
Octane - C ₈	0.0134			Calc'd Emissivity:	0.222		
Ethylene	0.0000			Tip ΔP:	22.65 in H ₂ O		
Propylene	0.0000			Tip Velocity:	293.0 fps		
Benzene	0.0000			Sonic Velocity:	1154.5 fps		
Toluene	0.0000			Mach Number:	0.25		
Ethylbenzene	0.0000			Flame Length (less assist air):	137.4 ft		
m-Xylene	0.0000			Min. Flare Height:	96.6 ft @base		
Total:	100.0			H2S Flare Height:	#VALUE! ft		
				# Pilots Req'd	2 ea		
Gas Assist Target LHV		btu/scf		U _{wind} /U _{exit}	0.10		
Assist Air:		scfm		Δx:	106.3 ft		
				Δy:	61.0 ft		
Radiation Criteria:				Sound level	124.9 db		
Max Rad@Base	1200	btu/hr.ft ²		Vmax=	566.5 ft/s		
Emissivity:	0.222			Air Assit Vmax=	126.5 ft/s		
Atm. Temp.	70	°F					
Relative Humidity:	50	%	Dist, horiz. (ft)	Radiation(btu/hr.ft²)	Rad Factor		
Wind velocity:	29.3	fps	0.0	976.5	0.81		
Flare Tip φ:	14	in	15.0	1051.2	0.81		
Flare Height(oah)	100	ft	30.0	1108.0	0.81		
Tip Press.	14.4	psia	50.0	1143.4	0.81		
Altitude	500	ft	75.0	1112.0	0.81		
Rad Factor:			100.0	1009.7	0.81		
			150.0	727.8	0.80		
			200.0	492.2	0.79		

Rev A



TECHNICAL DATA

DESCRIPTION: 14" UTILITY TIP WITH RETRACKTABLE PILOT ON
100' OAH GUYED STACK

CUSTOMER: Kinder Morgan

DESIGN PARAMETERS:

FLOW RATE: 28.400 mmscfd
TEMPERATURE: -8 °F
MOLECULAR WEIGHT: 21.43 lb/lb-mol
TIP PRESSURE DROP: 0.82 psig
EXIT VELOCITY: 293.0 fps
MACH NO.: 0.25

UTILITIES:

PURGE GAS (w/seal): 117.7 cfh
PURGE GAS (w/o seal): N/A
ASSIST GAS: N/A
PILOT GAS: 8-12 cfh @ 10 psig

ELECTRIC:

IGNITION: 3 amps @ 120V-1Ph-60Hz
CONTROLS: 3 amps @ 120V-1Ph-60Hz
BLOWER: N/A

ENVIRONMENTAL:

RADIATION ON GRADE @DESIGN FLOW RATE, Btu/SF/Hr:
(@Distance from base, ft) Wind@ 20.0 mph.
@ BASE 15 30 50 75 100 150 200
976.5 1051.2 1108.0 1143.4 1112.0 1009.7 727.8 492.2

NOTE: Radiation does not include solar radiation (approx. 250 btu/hr).


DESTRUCTION EFFICIENCY: 98%



Customer: Kinder Morgan
 Job: PRV

Wind Velocity: 20.0 mph

Radiation vs. Distance



NOTE: Radiation does not include solar radiation (approx. 250 btu/hr).

Recommended Design Total Radiation (from API RP-521)

Permissible Design Level (K) (BTU/hr ft ²)	Conditions
5000	Heat intensity on structures and in areas where operators are not likely to be performing duties and where shelter from radiant heat is available (for example, behind equipment).
3000	Value of K at design flare release at any location to which people have access (for example, at grade below the flare or a service platform of a nearby tower); exposure should be limited to a few seconds, sufficient for escape only.
2000	Heat intensity in areas where emergency actions lasting up to 1 minute may be required by personnel without shielding but with appropriate clothing.
1500	Heat intensity in areas where emergency actions lasting several minutes may be required by personnel without shielding but with appropriate clothing.
500	Value of K at any location where personnel with appropriate clothing may be continuously exposed.

APPENDIX C – Blocked Facility Outlet Scenario Details

Hydraulic Detailed Results

Knockout Drum Detailed Results

Flare Detailed Sizing Results

Relief Load Calculations



Targa Resources LLC
Valley Wells Compressor Station
Blocked Facility Outlet - 3 of 5 Compressor Running (C-1051, 1052 & 1057)

Client:	Targa Resources LLC		Increments/Seg.	5
Project:	Valley Wells Compressor Station		P Atm	14.7 psia
Project Number:	23-1005		Exit Pressure	2 psig
Date:	Mar-24		Roughness	0.00015 feet
Created by:	Rob Kreder		Friction dP Only	FALSE

Input Data						Calculated Values						Inlet Conditions				Exit Conditions				Results				
Description	Segment	Start Node	End Node	Pipe NPS	Pipe Sch	Pipe ID (inches)	Equivalent Length (ft)	Segment Flow (lb/hr)	Segment Flow (MMSCFD)	Moody f	Fluid MW	P ₁ (psig)	T ₁ (F)	K ₁	ρ ₁ (lb/ft ³)	P ₂ (psig)	T ₂ (F)	K ₂	Z ₂	Segment ΔP (psi)	Max. Velocity (ft/sec)	Sonic Velocity (ft/sec)	Segment Max. Mach Number	Choke P at Segment Exit (psig)
Reducer To Flare Base	S-1005	N-1010	N-1000	12"	STD	12.000	2.0	189,329	79.14	0.013	21.79	5.2	194.4	1.206	0.062	2.0	194.2	1.206	0.052	3.2	1287.7	1341.9	0.96	1.3
KO Drum to Reducer	S-1015	N-1020	N-1010	20"	20	19.250	86.4	189,329	79.14	0.012	21.79	6.1	194.4	1.206	0.065	5.2	194.4	1.206	0.062	0.9	419.7	1342.1	0.31	-8.5
KO Drum	S-1025	N-1030	N-1020	20"	20	19.250	66.8	189,329	79.14	0.012	21.79	6.8	194.5	1.206	0.067	6.1	194.4	1.206	0.065	0.6	400.3	1342.1	0.30	-8.5
V-1917 Tie In to KO Drum	S-1035	N-1040	N-1030	20"	20	19.250	575.4	189,329	79.14	0.012	21.79	11.5	194.7	1.206	0.082	6.8	194.5	1.206	0.067	4.7	388.4	1342.2	0.29	-8.5
V-1912 to V-1917 Tie In	S-1045	N-1050	N-1040	20"	20	19.250	25.0	189,329	79.14	0.012	21.79	11.7	194.7	1.206	0.082	11.5	194.7	1.206	0.082	0.2	317.3	1342.4	0.24	-8.5
Sulfatreat to V-1912 Tie In	S-1055	N-1060	N-1050	20"	20	19.250	69.8	189,329	79.14	0.012	21.79	12.2	194.8	1.206	0.084	11.7	194.7	1.206	0.082	0.5	317.3	1342.4	0.24	-8.5
Compressor Sub to Sulfatreat Tie In	S-1065	N-1070	N-1060	20"	20	19.250	25.0	189,329	79.14	0.012	21.79	12.4	194.8	1.206	0.084	12.2	194.8	1.206	0.084	0.2	309.8	1342.5	0.23	-8.5
Common Compressor Subheader @1	S-1075	N-2000	N-1070	12"	STD	12.000	114.0	189,329	79.14	0.013	21.79	22.8	195.4	1.206	0.117	12.4	194.8	1.206	0.084	10.4	797.2	1342.5	0.59	1.3
West Compressor Subheader #1	S-2005	N-2010	N-2000	12"	STD	12.000	112.0	118,157	49.39	0.013	21.79	25.3	194.9	1.206	0.125	22.8	194.7	1.206	0.117	2.5	357.2	1342.4	0.27	-4.7
West Compressor Subheader #2	S-2035	N-2040	N-2010	12"	STD	12.000	80.0	118,157	49.39	0.013	21.79	27.0	195.0	1.206	0.130	25.3	194.9	1.206	0.125	1.7	334.3	1342.6	0.25	-4.7
C-1052 Subheader #1	S-2045	N-2050	N-2040	8"	40	7.981	80.5	46,985	19.64	0.014	21.79	29.1	192.5	1.206	0.137	27.0	192.4	1.206	0.131	2.1	286.8	1340.0	0.21	-5.7
C-1052 Subheader #2	S-2055	N-2060	N-2050	8"	40	7.981	26.9	46,985	19.64	0.014	21.79	29.8	192.6	1.206	0.140	29.1	192.5	1.206	0.137	0.7	274.2	1340.1	0.20	-5.7
C-1052 Subheader #3	S-2075	N-2080	N-2060	8"	40	7.981	37.0	46,985	19.64	0.014	21.79	30.8	192.6	1.206	0.142	29.8	192.6	1.206	0.140	0.9	268.3	1340.2	0.20	-5.8
C-1052 Subheader #4	S-2095	N-2100	N-2080	8"	40	7.981	18.3	46,985	19.64	0.014	21.79	31.2	192.6	1.206	0.144	30.8	192.6	1.206	0.142	0.5	264.6	1340.2	0.20	-5.8
PSV-1052A to Subheader	S-2105	N-2110	N-2100	3"	40	3.068	9.6	46,985	19.64	0.017	21.79	93.7	196.2	1.206	0.341	45.8	193.5	1.206	0.190	47.8	1340.2	1340.2	1.00	45.8
West Compressor Subheader #2	S-2155	N-2160	N-2040	12"	STD	12.000	80.0	71,172	29.75	0.013	21.79	27.6	196.7	1.206	0.132	27.0	196.7	1.206	0.130	0.6	193.6	1344.4	0.14	-8.7
C-1051 Subheader #1	S-2165	N-2170	N-2160	8"	40	7.981	87.9	71,172	29.75	0.014	21.79	33.0	197.0	1.206	0.148	27.6	196.7	1.206	0.132	5.3	431.1	1344.4	0.32	-1.1
C-1051 Subheader #2	S-2175	N-2180	N-2170	8"	40	7.981	40.3	71,172	29.75	0.014	21.79	35.2	197.1	1.206	0.155	33.0	197.0	1.206	0.148	2.2	384.5	1344.7	0.29	-1.1
C-1051 Subheader #3	S-2205	N-2210	N-2180	8"	40	7.981	20.6	71,172	29.75	0.014	21.79	36.3	197.2	1.206	0.159	35.2	197.1	1.206	0.155	1.1	367.1	1344.8	0.27	-1.1
C-1051 Subheader #4	S-2225	N-2230	N-2210	8"	40	7.981	18.3	71,172	29.75	0.014	21.79	37.2	197.2	1.205	0.162	36.3	197.2	1.206	0.159	0.9	357.9	1344.9	0.27	-1.1
PSV-1051A to Subheader	S-2235	N-2240	N-2230	3"	40	3.068	9.6	46,985	19.64	0.017	21.79	93.7	196.2	1.206	0.341	45.8	193.5	1.206	0.190	47.9	1340.6	1340.6	1.00	45.8
East Compressor Subheader	S-2215	N-2220	N-2000	12"	STD	12.000	208.0	71,172	29.75	0.013	21.79	24.4	196.5	1.206	0.122	22.8	196.4	1.206	0.117	1.7	215.1	1344.1	0.16	-8.7
C-1057 Subheader #1	S-2225	N-2230	N-2220	6"	40	6.065	46.6	71,172	29.75	0.015	21.79	39.1	197.3	1.205	0.168	24.4	196.5	1.206	0.122	14.7	807.7	1344.2	0.60	8.9
C-1057 Subheader #2	S-2245	N-2250	N-2230	6"	40	6.065	18.0	24,187	10.11	0.015	21.79	37.7	205.5	1.204	0.161	37.2	205.4	1.204	0.160	0.4	209.3	1352.2	0.15	-6.6
C-1057 Subheader #3	S-2265	N-2270	N-2250	6"	40	6.065	40.3	24,187	10.11	0.015	21.79	38.6	205.5	1.204	0.164	37.7	205.5	1.204	0.161	0.9	208.0	1352.3	0.15	-6.6
PSV-1057A to Subheader	S-2275	N-2280	N-2270	3"	40	3.068	4.6	24,187	10.11	0.017	21.79	44.1	205.8	1.204	0.181	38.6	205.5	1.204	0.164	5.5	798.0	1352.3	0.59	16.8



Targa Resources LLC
Valley Wells Compressor Station
Blocked Facility Outlet - 3 of 5 Compressor Running (C-1051, 1052 & 1057)

Client:	Targa Resources LLC
Project:	Valley Wells Compressor Station
Project Number:	23-1005
Date:	Mar-24
Created by:	Rob Kreder

Segment Data																					
Description	Segment	Start Node	End Node	Pipe NPS	Pipe Sch	Pipe ID (inches)	Moody F	Pipe Length (ft)	# 90 Elbows	Eq. Length 90 Elbows	# 45 Elbows	Eq. Length 45 Elbows	Entrances	Eq. Length Entrances	Tee Through	Eq. Length Tee Through	Tee Branch	Eq. Length Tee Branch	Ball Valve	Eq. Length Ball Valve	Equivalent Length (ft)
Reducer To Flare Base	S-1005	N-1010	N-1000	12"	STD	12.000	0.013	2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	2.0
KO Drum to Reducer	S-1015	N-1020	N-1010	20"	20	19.250	0.012	19	3	67.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	86.4
KO Drum	S-1025	N-1030	N-1020	20"	20	19.250	0.012	0	0	0.0	0	0.0	1	66.8	0	0.0	0	0.0	0	0.0	66.8
V-1917 Tie In to KO Drum	S-1035	N-1040	N-1030	20"	20	19.250	0.012	508	3	67.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	575.4
V-1912 to V-1917 Tie In	S-1045	N-1050	N-1040	20"	20	19.250	0.012	25	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	25.0
Sulfatreat to V-1912 Tie In	S-1055	N-1060	N-1050	20"	20	19.250	0.012	65	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	1	4.8	69.8
Compressor Sub to Sulfatreat Tie In	S-1065	N-1070	N-1060	20"	20	19.250	0.012	25	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	25.0
Common Compressor Subheader @1	S-1075	N-2000	N-1070	12"	STD	12.000	0.013	23	2	28.0	0	0.0	0	0.0	0	0.0	1	60.0	1	3.0	114.0
West Compressor Subheader #1	S-2005	N-2010	N-2000	12"	STD	12.000	0.013	52	0	0.0	0	0.0	0	0.0	0	0.0	1	60.0	0	0.0	112.0
West Compressor Subheader #2	S-2035	N-2040	N-2010	12"	STD	12.000	0.013	60	0	0.0	0	0.0	0	0.0	1	20.0	0	0.0	0	0.0	80.0
C-1052 Subheader #1	S-2045	N-2050	N-2040	8"	40	7.981	0.014	28	0	0.0	2	10.6	0	0.0	0	0.0	1	39.9	1	2.0	80.5
C-1052 Subheader #2	S-2055	N-2060	N-2050	8"	40	7.981	0.014	1	0	0.0	2	10.6	0	0.0	1	13.3	0	0.0	1	2.0	26.9
C-1052 Subheader #3	S-2075	N-2080	N-2060	8"	40	7.981	0.014	17	1	9.3	2	10.6	0	0.0	0	0.0	0	0.0	0	0.0	37.0
C-1052 Subheader #4	S-2095	N-2100	N-2080	8"	40	7.981	0.014	5	0	0.0	0	0.0	0	0.0	1	13.3	0	0.0	0	0.0	18.3
PSV-1052A to Subheader	S-2105	N-2110	N-2100	3"	40	3.068	0.018	6	1	3.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	9.6
West Compressor Subheader #2	S-2155	N-2160	N-2040	12"	STD	12.000	0.013	60	0	0.0	0	0.0	0	0.0	1	20.0	0	0.0	0	0.0	80.0
C-1051 Subheader #1	S-2165	N-2170	N-2160	8"	40	7.981	0.014	26	1	9.3	2	10.6	0	0.0	0	0.0	1	39.9	1	2.0	87.9
C-1051 Subheader #2	S-2175	N-2180	N-2170	8"	40	7.981	0.014	7	1	9.3	2	10.6	0	0.0	1	13.3	0	0.0	0	0.0	40.3
C-1051 Subheader #3	S-2205	N-2210	N-2180	8"	40	7.981	0.014	10	0	0.0	2	10.6	0	0.0	0	0.0	0	0.0	0	0.0	20.6
C-1051 Subheader #4	S-2225	N-2230	N-2210	8"	40	7.981	0.014	5	0	0.0	0	0.0	0	0.0	1	13.3	0	0.0	0	0.0	18.3
PSV-1051A to Subheader	S-2235	N-2240	N-2230	3"	40	3.068	0.018	6	1	3.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	9.6
East Compressor Subheader	S-2215	N-2220	N-2000	12"	STD	12.000	0.013	128	0	0.0	0	0.0	0	0.0	1	20.0	1	60.0	0	0.0	208.0
C-1057 Subheader #1	S-2225	N-2230	N-2220	6"	40	6.065	0.015	41	0	0.0	1	4.0	0	0.0	0	0.0	0	0.0	1	1.5	46.6
C-1057 Subheader #2	S-2245	N-2250	N-2230	6"	40	6.065	0.015	18	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	18.0
C-1057 Subheader #3	S-2265	N-2270	N-2250	6"	40	6.065	0.015	8	2	14.2	2	8.1	0	0.0	1	10.1	0	0.0	0	0.0	40.3
PSV-1057A to Subheader	S-2275	N-2280	N-2270	3"	40	3.068	0.018	1	1	3.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	4.6

Targa Resources LLC
Valley Wells Compressor Station
Blocked Facility Outlet - 3 of 5 Compressor Running (C-1051, 1052 & 1057)
Flare Knockout Drum Evaluation

Inputs		
Density (Liquid)	40.00	lb/ft ³
Total Liquid In Flow	0	BPD
Low Liquid Level	7%	
Normal Liquid Level	14%	
High Liquid Level	30%	
Minimum Droplet Size	723	microns
Vessel Inner Diameter	6	ft
Selected Vessel Length	20	ft
Results from Hydraulic Evaluation		
Vapor Flowrate	79.14	MMSCFD
Operating Temperature	194.50	F
Operating Pressure	6.77	psig
Atmospheric Pressure	14.7	psia
MW (Vapor)	21.79	
Viscosity (Vapor)	0.01	cp
Density (Vapor)	0.067	lb/ft ³
Mass Flowrate	52.7	lb/s
Volumetric Flowrate	786.0	ft ³ /sec
Calculate Terminal Settling Velocity		
Minimum Droplet Size	0.002372	ft
c'(Re)^2	33916.0	
Drag Coefficient C'	0.71	
Terminal Settling Velocity	9.22	ft/s
Calculate Vessel Nozzle Separation Based on Low Level		
Full Area	28.3	ft ²
Required Fall Distance	5.6	ft
Required Residence Time	0.6	sec
Gas Velocity	27.80	ft/sec
Min. Nozzle Separation	16.8	ft
Calculate Vessel Nozzle Separation Based on Normal Level		
Level	0.8	ft
Required Fall Distance	5.2	ft
Required Residence Time	0.6	sec
α	43.9	degrees
x	2.1	ft
Circular Area	21.4	ft ²
Triangle Area	4.5	ft ²
Cross-Sectional Area	25.9	ft ²
Gas Velocity	30.38	ft/sec
Min. Nozzle Separation	17.0	ft
Calculate Vessel Nozzle Separation Based on High Level		
Level	1.8	ft
Required Fall Distance	4.2	ft
Required Residence Time	0.5	sec
α	66.4	degrees
x	2.7	ft
Circular Area	17.8	ft ²
Triangle Area	3.3	ft ²
Cross-Sectional Area	21.1	ft ²
Gas Velocity	37.18	ft/sec
Min. Nozzle Separation	16.9	ft

Targa Resources LLC
Valley Wells Compressor Station
Blocked Facility Outlet - 3 of 5 Compressor Running (C-1051, 1052 & 1057)
Flare Tip Radiation and Exit Velocity


Inputs

Atmospheric Pressure	P_{atm}	14.7	psia
Mass Flowrate	q_m	189,329	lb/hr
Temperature	T_j	194	F
Molecular Weight	M_j	21.79	lb/lbmole
Compressibility	Z_j	0.99	
Heat of Combustion	LHV	20,693	Btu/lb
Flare Inner Diameter	d_j	1.17	ft
Flare Height	h	100	ft
Fraction Heat Radiated	F	0.16	
Wind Speed	u_j	20	mph
Ambient Temperature	T_∞	60	F
Horizontal Distance to Flame Center	x_c	13	ft
Vertical Distance to Flame Center	y_c	50	ft


Outputs

Exit Mach Number	Ma_2	0.88	
Isothermal Sonic Velocity	u_s	1222.1	ft/sec
Exit Velocity	u_j	1073.2	ft/sec
Mixture LEL	C_L	4.82	vol %
Wind Speed	u_j	29.3	ft/sec
LEL Concentration Parameter	C_L	1.326	
Jet and Wind Thrust	$d_j R$	177.6	
Heat Released	Q	3,918	MMBtu/hr
Flame Center Height	h'	150	ft


Radiation Level	Distance from Base d_b (ft)	Distance from Center d_c (ft)
200	489	499
300	392	408
400	333	353
500	291	316
600	259	288
700	234	267
800	213	250
900	194	235
1,000	178	223
1,100	164	213
1,200	151	204
1,300	139	196
1,400	128	189
1,500	117	182
1,600	106	177
1,700	96	171
1,800	85	166
1,900	74	162
2,000	62	158
2,100	48	154
2,200	26	151
2,300	N/A	147
2,350	N/A	146
2,450	N/A	143
2,550	N/A	140



Radiation Versus Distance from Base of Stack Blocked Facility Outlet - 3 of 5 Compressors Running (C-1051, 1052 & 1057)



API Standard 521 / ISO 23251



Key

- X \overline{C}_L , the lower-explosive-limit concentration parameter for the flare gas, see Equation (C.7)
- Y y_c , vertical distance from the stack to flame centre, expressed in feet
- ^a $(d_j R)$ is the parameter for jet thrust and wind thrust, see Equation (C.8).

Figure C.5 — Flame centre for flares and ignited vents — Vertical distance, y_c (USC units)

C.3.4 Calculation of the distance from the flame centre to the object or point being considered

The design basis for this calculation is as follows: The fraction of heat radiated, F , is 0,3. The heat liberated (see C.2.3), Q , is $6,3 \times 10^6$ kW ($2,15 \times 10^{10}$ Btu/h). Say the flare stack design must limit the maximum allowable radiation (see 6.4.2.3), K , is $9,5$ kW/m² (3 000 Btu/h·ft²).

In Equation (24), the value of τ should be assumed to be 1,0 (see C.3.6.3 and C.3.6.4). The distance from the flame centre to the object or point being considered (that is, the distance to the limit of the radiant heat intensity, such as grade level, an equipment platform, or a plant boundary), D , is then calculated as follows:


$$D = \sqrt{\frac{\tau \cdot F \cdot Q}{4\pi \cdot K}} \tag{24}$$

In SI units:

$$D = \sqrt{\frac{1,0 \times 0,3 \times 6,3 \times 10^6}{4\pi \times 9,5}} = 126 \text{ m}$$

Targa Resources LLC
 Valley Wells Compressor Station
 Blocked Facility Outlet - 3 of 5 Compressor Running (C-1051, 1052 & 1057)
 Horizontal Distance to Flame Center - API STD 521 Figure C-5

API Standard 521 / ISO 23251



Key

X \bar{C}_L , the lower-explosive-limit concentration parameter for the flare gas, see Equation (C.7)

Y x_c , horizontal distance from the stack to flame centre, expressed in feet

^a $(d_j R)$ is the parameter for jet thrust and wind thrust, see Equation (C.8).

Figure C.3 — Flame centre for flares and ignited vents — Horizontal distance, x_c (USC units)

Blocked Reciprocating Compressor



Equipment Data:

Equipment Tag:	V-9432 (C-1051)	Type:	Pressure Vessel
Drawing:	D-2415-F-03C	MAWP:	1450 psig
Description:	C-1051 3rd Stage Discharge Bottle	MAWT:	350 F

Scenario Description:

In the event that of a blocked discharge, this reciprocating compressor could be overpressured. The relief requirement was based on the normal suction gas composition with the 3rd stage suction set at the PSHH set point of 570 psig (per recommendation for PSHH reset on PSV-1051B) and 120 F. The mechanical characteristics of the compressor at 1,000 rpm and minimum clearances were used in the evaluation.

Scenario Calculation Results:

Required Rate:	19.7	MMSCFD	Device Choke Pressure:	889.7	psig
Actual Capacity:	29.4	MMSCFD	Outlet Temperature:	190.6	F
Required Area:	0.577	in ²	Outlet Mass Quality:	1.000	
Actual Area:	0.865	in ²	Outlet Density:	0.045	lb/ft ³
Relief Pressure:	1584.0	psig	Outlet Ideal Cp/Cv:	1.207	
Relief Temperature:	259.8	F	Outlet Viscosity:	0.012	cP
Relief MW:	21.78		Inlet Non-Recoverble dP:	10.7	psi
Relief Mass Quality:	1.000		Inlet dP % Set:	0.7	% Set
Relief Density:	5.093	lb/ft ³	Built-Up Back Pressure:	147.5	psig
Relief SG:	0.751		Built-Up Back P % Set:	10.2	% Set
Relief Z:	0.89		Total Back Pressure:	147.5	psig
Relief Ideal Cp/Cv:	1.194		Total Back P % Set:	10.2	% Set
Relief Viscosity:	0.013	cP			

Exit Velocity at Reseat Capacity is too low.

Blocked Reciprocating Compressor



Equipment Data:

Equipment Tag:	V-9432 (C-1051)	Type:	Pressure Vessel
Drawing:	D-2415-F-03C	MAWP:	1450 psig
Description:	C-1051 3rd Stage Discharge Bottle	MAWT:	350 F

Scenario Input Data:

Gas Type:	Inlet Gas
Number of Cylinders:	1
Cylinder Type:	Double Acting
Compressor RPM	1000
Compressor Stroke	6.75 in
Cylinder Diameter:	9.125 in
Rod Diameter:	2.875 in
Head End Clearance %:	15.59 %
Crank End Clearance %:	18.38 %
Suction Valve Losses %:	7 %
Discharge Valve Losses %:	7 %
Required Relief Rate Units:	MMSCFD
Suction Pressure:	570 psig
Dewpoint Vapor:	<input type="checkbox"/>
Suction Temperature:	120 F
Set Pressure:	1440 psig
Allowable Overpressure:	10.0%
Device Outlet Pressure:	0 psig
Use Thermo	<input checked="" type="checkbox"/>
Thermo Package:	Advanced_Peng-Robinson
Relief Device Kd:	0.818
Nozzle Sizing:	API 520 Vapor
Outlet Pipe Sizing:	Isothermal

Scenario Output Data:

HE Displacement:	255.5 acfm
CE Displacement:	230.1 acfm
HE Volumetric Efficiency:	70.7 %
CE Volumetric Efficiency:	67.2 %
Compression Ratio:	2.735
Suction Z:	0.876
Suction Ideal Cp/Cv:	1.222
Required Mass Rate:	46,985.0 lb/hr
Required Rate Std. Volume:	19.65 MMSCFD
Required Air Rate:	834,717.5 scfh air
Relief Mass Flux:	3255.4 lb/sec/ft2

Notes:

Blocked Reciprocating Compressor



Equipment Data:

Equipment Tag:	V-9432 (C-1051)	Type:	Pressure Vessel
Drawing:	D-2415-F-03C	MAWP:	1450 psig
Description:	C-1051 3rd Stage Discharge Bottle	MAWT:	350 F

Relief Stream Composition:

Stream Description: Valley Wells 3rd Suction Gas

Component	Mole Fraction
hydrogen sulfide	0.0003
nitrogen	0.0016
methane	0.7626
carbon dioxide	0.0027
ethane	0.1316
propane	0.0578
butane	0.0193
isobutane	0.0084
ipentane	0.0053
isopentane	0.0047
hexane	0.0015
cyclohexane	0.0010
heptane	0.0003
octane	0.0012
benzene	0.0007
ethylbenzene	0.0009

Blocked Reciprocating Compressor



Equipment Data:

Equipment Tag:	V-9432 (C-1052)	Type:	Pressure Vessel
Drawing:	D-2415-F-04C	MAWP:	1450 psig
Description:	C-1052 3rd Stage Discharge Bottle	MAWT:	350 F

Scenario Description:

In the event that of a blocked discharge, this reciprocating compressor could be overpressured. The relief requirement was based on the normal suction gas composition with the 3rd stage suction set at the PSHH set point of 570 psig (per recommendation for PSHH reset on PSV-1051B) and 120 F. The mechanical characteristics of the compressor at 1,000 rpm and minimum clearances were used in the evaluation.

Scenario Calculation Results:

Required Rate:	19.7	MMSCFD	Device Choke Pressure:	889.7	psig
Actual Capacity:	29.4	MMSCFD	Outlet Temperature:	190.6	F
Required Area:	0.577	in ²	Outlet Mass Quality:	1.000	
Actual Area:	0.865	in ²	Outlet Density:	0.045	lb/ft ³
Relief Pressure:	1584.0	psig	Outlet Ideal Cp/Cv:	1.207	
Relief Temperature:	259.8	F	Outlet Viscosity:	0.012	cP
Relief MW:	21.78		Inlet Non-Recoverble dP:	10.7	psi
Relief Mass Quality:	1.000		Inlet dP % Set:	0.7	% Set
Relief Density:	5.093	lb/ft ³	Built-Up Back Pressure:	147.5	psig
Relief SG:	0.751		Built-Up Back P % Set:	10.2	% Set
Relief Z:	0.89		Total Back Pressure:	147.5	psig
Relief Ideal Cp/Cv:	1.194		Total Back P % Set:	10.2	% Set
Relief Viscosity:	0.013	cP			

Exit Velocity at Reseat Capacity is too low.

Blocked Reciprocating Compressor



Equipment Data:

Equipment Tag:	V-9432 (C-1052)	Type:	Pressure Vessel
Drawing:	D-2415-F-04C	MAWP:	1450 psig
Description:	C-1052 3rd Stage Discharge Bottle	MAWT:	350 F

Scenario Input Data:

Gas Type:	Inlet Gas
Number of Cylinders:	1
Cylinder Type:	Double Acting
Compressor RPM	1000
Compressor Stroke	6.75 in
Cylinder Diameter:	9.125 in
Rod Diameter:	2.875 in
Head End Clearance %:	15.59 %
Crank End Clearance %:	18.38 %
Suction Valve Losses %:	7 %
Discharge Valve Losses %:	7 %
Required Relief Rate Units:	MMSCFD
Suction Pressure:	570 psig
Dewpoint Vapor:	<input type="checkbox"/>
Suction Temperature:	120 F
Set Pressure:	1440 psig
Allowable Overpressure:	10.0%
Device Outlet Pressure:	0 psig
Use Thermo	<input checked="" type="checkbox"/>
Thermo Package:	Advanced_Peng-Robinson
Relief Device Kd:	0.818
Nozzle Sizing:	API 520 Vapor
Outlet Pipe Sizing:	Isothermal

Scenario Output Data:

HE Displacement:	255.5 acfm
CE Displacement:	230.1 acfm
HE Volumetric Efficiency:	70.7 %
CE Volumetric Efficiency:	67.2 %
Compression Ratio:	2.735
Suction Z:	0.876
Suction Ideal Cp/Cv:	1.222
Required Mass Rate:	46,985.0 lb/hr
Required Rate Std. Volume:	19.65 MMSCFD
Required Air Rate:	834,717.5 scfh air
Relief Mass Flux:	3255.4 lb/sec/ft2

Notes:

Blocked Reciprocating Compressor



Equipment Data:

Equipment Tag:	V-9432 (C-1052)	Type:	Pressure Vessel
Drawing:	D-2415-F-04C	MAWP:	1450 psig
Description:	C-1052 3rd Stage Discharge Bottle	MAWT:	350 F

Relief Stream Composition:

Stream Description: Valley Wells 3rd Suction Gas

Component	Mole Fraction
hydrogen sulfide	0.0003
nitrogen	0.0016
methane	0.7626
carbon dioxide	0.0027
ethane	0.1316
propane	0.0578
butane	0.0193
isobutane	0.0084
ipentane	0.0053
isopentane	0.0047
hexane	0.0015
cyclohexane	0.0010
heptane	0.0003
octane	0.0012
benzene	0.0007
ethylbenzene	0.0009

Blocked Reciprocating Compressor



Equipment Data:

Equipment Tag:	V-9432 (C-1057)	Type:	Pressure Vessel
Drawing:	D-2415-F-09C	MAWP:	1450 psig
Description:	C-1057 3rd Stage Discharge Bottle	MAWT:	350 F

Scenario Description:

In the event that of a blocked discharge, this reciprocating compressor could be overpressured. The relief requirement was based on the normal suction gas composition with the 3rd stage suction set at the PSHH set point of 525 psig and 120 F. The mechanical characteristics of the compressor at 1,000 rpm and minimum clearances were used in the evaluation.

Scenario Calculation Results:

Required Rate:	10.1	MMSCFD	Device Choke Pressure:	890.3	psig
Actual Capacity:	11.3	MMSCFD	Outlet Temperature:	203.7	F
Required Area:	0.301	in ²	Outlet Mass Quality:	1.000	
Actual Area:	0.337	in ²	Outlet Density:	0.044	lb/ft ³
Relief Pressure:	1584.0	psig	Outlet Ideal Cp/Cv:	1.204	
Relief Temperature:	270.2	F	Outlet Viscosity:	0.012	cP
Relief MW:	21.78		Inlet Non-Recoverble dP:	1.6	psi
Relief Mass Quality:	1.000		Inlet dP % Set:	0.1	% Set
Relief Density:	4.976	lb/ft ³	Built-Up Back Pressure:	128.5	psig
Relief SG:	0.751		Built-Up Back P % Set:	8.9	% Set
Relief Z:	0.89		Total Back Pressure:	128.5	psig
Relief Ideal Cp/Cv:	1.192		Total Back P % Set:	8.9	% Set
Relief Viscosity:	0.013	cP			

Exit Velocity at Reseat Capacity is too low.

Blocked Reciprocating Compressor



Equipment Data:

Equipment Tag:	V-9432 (C-1057)	Type:	Pressure Vessel
Drawing:	D-2415-F-09C	MAWP:	1450 psig
Description:	C-1057 3rd Stage Discharge Bottle	MAWT:	350 F

Scenario Input Data:

Gas Type:	Inlet Gas
Number of Cylinders:	1
Cylinder Type:	Double Acting
Compressor RPM	1000
Compressor Stroke	6.5 in
Cylinder Diameter:	7.25 in
Rod Diameter:	2.5 in
Head End Clearance %:	16.46 %
Crank End Clearance %:	19.71 %
Suction Valve Losses %:	7 %
Discharge Valve Losses %:	7 %
Required Relief Rate Units:	MMSCFD
Suction Pressure:	525 psig
Dewpoint Vapor:	<input type="checkbox"/>
Suction Temperature:	120 F
Set Pressure:	1440 psig
Allowable Overpressure:	10.0%
Device Outlet Pressure:	0 psig
Use Thermo	<input checked="" type="checkbox"/>
Thermo Package:	Advanced_Peng-Robinson
Relief Device Kd:	0.818
Nozzle Sizing:	API 520 Vapor
Outlet Pipe Sizing:	Isothermal

Scenario Output Data:

HE Displacement:	155.3 acfm
CE Displacement:	136.8 acfm
HE Volumetric Efficiency:	66.82 %
CE Volumetric Efficiency:	62.23 %
Compression Ratio:	2.963
Suction Z:	0.885
Suction Ideal Cp/Cv:	1.222
Required Mass Rate:	24,186.7 lb/hr
Required Rate Std. Volume:	10.11 MMSCFD
Required Air Rate:	432,799.9 scfh air
Relief Mass Flux:	3215.6 lb/sec/ft2

Notes:

Blocked Reciprocating Compressor



Equipment Data:

Equipment Tag:	V-9432 (C-1057)	Type:	Pressure Vessel
Drawing:	D-2415-F-09C	MAWP:	1450 psig
Description:	C-1057 3rd Stage Discharge Bottle	MAWT:	350 F

Relief Stream Composition:

Stream Description: Valley Wells 3rd Suction Gas

Component	Mole Fraction
hydrogen sulfide	0.0003
nitrogen	0.0016
methane	0.7626
carbon dioxide	0.0027
ethane	0.1316
propane	0.0578
butane	0.0193
isobutane	0.0084
ipentane	0.0053
isopentane	0.0047
hexane	0.0015
cyclohexane	0.0010
heptane	0.0003
octane	0.0012
benzene	0.0007
ethylbenzene	0.0009

APPENDIX D – Fire Zone #1 – C-1051 & C-1052 Details

Hydraulic Detailed Results

Knockout Drum Detailed Results

Flare Detailed Sizing Results

Relief Load Calculations



Targa Resources LLC
Valley Wells Compressor Station
External Fire Zone #1 - C-1051 and C-1052

Client:	Targa Resources LLC
Project:	Valley Wells Compressor Station
Project Number:	23-1005
Date:	Mar-24
Created by:	Rob Kreder

Segment Data																					
Description	Segment	Start Node	End Node	Pipe NPS	Pipe Sch	Pipe ID (inches)	Moody F	Pipe Length (ft)	# 90 Elbows	Eq. Length 90 Elbows	# 45 Elbows	Eq. Length 45 Elbows	Entrances	Eq. Length Entrances	Tee Through	Eq. Length Tee Through	Tee Branch	Eq. Length Tee Branch	Ball Valve	Eq. Length Ball Valve	Equivalent Length (ft)
Reducer To Flare Base	S-1005	N-1010	N-1000	12"	STD	12.000	0.013	2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	2.0
KO Drum to Reducer	S-1015	N-1020	N-1010	20"	20	19.250	0.012	19	3	67.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	86.4
KO Drum	S-1025	N-1030	N-1020	20"	20	19.250	0.012	0	0	0.0	0	0.0	1	66.8	0	0.0	0	0.0	0	0.0	66.8
V-1917 Tie In to KO Drum	S-1035	N-1040	N-1030	20"	20	19.250	0.012	508	3	67.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	575.4
V-1912 to V-1917 Tie In	S-1045	N-1050	N-1040	20"	20	19.250	0.012	25	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	25.0
Sulfatreat to V-1912 Tie In	S-1055	N-1060	N-1050	20"	20	19.250	0.012	65	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	1	4.8	69.8
Compressor Sub to Sulfatreat Tie In	S-1065	N-1070	N-1060	20"	20	19.250	0.012	25	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	25.0
Common Compressor Subheader @1	S-1075	N-2000	N-1070	12"	STD	12.000	0.013	23	2	28.0	0	0.0	0	0.0	0	0.0	1	60.0	1	3.0	114.0
West Compressor Subheader #1	S-2005	N-2010	N-2000	12"	STD	12.000	0.013	52	0	0.0	0	0.0	0	0.0	0	0.0	1	60.0	0	0.0	112.0
West Compressor Subheader #2	S-2035	N-2040	N-2010	12"	STD	12.000	0.013	60	0	0.0	0	0.0	0	0.0	1	20.0	0	0.0	0	0.0	80.0
C-1052 Subheader #1	S-2045	N-2050	N-2040	8"	40	7.981	0.014	28	0	0.0	2	10.6	0	0.0	0	0.0	1	39.9	1	2.0	80.5
C-1052 Subheader #2	S-2055	N-2060	N-2050	8"	40	7.981	0.014	1	0	0.0	2	10.6	0	0.0	1	13.3	0	0.0	1	2.0	26.9
PSV-1052E to Subheader 2"	S-2063	N-2065	N-2060	2"	80	1.939	0.019	4	4	9.0	0	0.0	0	0.0	1	3.2	0	0.0	0	0.0	16.3
PSV-1052E to Subheader 1"	S-2068	N-2070	N-2065	1"	80	0.957	0.023	1.5	2	2.2	0	0.0	0	0.0	0	0.0	1	4.8	0	0.0	8.5
C-1052 Subheader #3	S-2075	N-2080	N-2060	8"	40	7.981	0.014	17	1	9.3	2	10.6	0	0.0	0	0.0	0	0.0	0	0.0	37.0
PSV-1052B to Subheader	S-2085	N-2090	N-2080	4"	40	4.026	0.017	1.5	2	9.4	0	0.0	0	0.0	0	0.0	1	20.1	0	0.0	31.0
C-1052 Subheader #4	S-2095	N-2100	N-2080	8"	40	7.981	0.014	5	0	0.0	0	0.0	0	0.0	1	13.3	0	0.0	0	0.0	18.3
PSV-1052A to Subheader	S-2105	N-2110	N-2100	3"	40	3.068	0.018	6	1	3.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	9.6
C-1052 Subheader #5	S-2115	N-2120	N-2050	8"	40	7.981	0.014	2	0	0.0	0	0.0	0	0.0	0	0.0	1	39.9	0	0.0	41.9
C-1052 Subheader #6	S-2125	N-2130	N-2120	6"	40	6.065	0.015	19	1	7.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	26.1
PSV-1052 NEW to Subheader	S-2135	N-2140	N-2130	3"	40	3.068	0.018	4	1	3.6	0	0.0	0	0.0	0	0.0	1	15.3	0	0.0	22.9
PSV-1052C to Subheader	S-2145	N-2150	N-2130	6"	40	6.065	0.015	38	2	14.2	0	0.0	0	0.0	1	10.1	0	0.0	0	0.0	62.3
West Compressor Subheader #2	S-2155	N-2160	N-2040	12"	STD	12.000	0.013	60	0	0.0	0	0.0	0	0.0	1	20.0	0	0.0	0	0.0	80.0
C-1051 Subheader #1	S-2165	N-2170	N-2160	8"	40	7.981	0.014	26	1	9.3	2	10.6	0	0.0	0	0.0	1	39.9	1	2.0	87.9
C-1051 Subheader #2	S-2175	N-2180	N-2170	8"	40	7.981	0.014	7	1	9.3	2	10.6	0	0.0	1	13.3	0	0.0	0	0.0	40.3
PSV-1051E to Subheader 2"	S-2185	N-2190	N-2180	2"	80	1.939	0.019	3	2	4.5	2	2.6	0	0.0	1	3.2	0	0.0	0	0.0	13.3
PSV-1051E to Subheader 1"	S-2195	N-2200	N-2190	1"	80	0.957	0.023	1	2	2.2	0	0.0	0	0.0	0	0.0	1	4.8	0	0.0	8.0
C-1051 Subheader #3	S-2205	N-2210	N-2180	8"	40	7.981	0.014	10	0	0.0	2	10.6	0	0.0	0	0.0	0	0.0	0	0.0	20.6
PSV-1051B to Subheader	S-2215	N-2220	N-2210	4"	40	4.026	0.017	1.5	2	9.4	0	0.0	0	0.0	0	0.0	1	20.1	0	0.0	31.0
C-1051 Subheader #4	S-2225	N-2230	N-2210	8"	40	7.981	0.014	5	0	0.0	0	0.0	0	0.0	1	13.3	0	0.0	0	0.0	18.3
PSV-1051A to Subheader	S-2235	N-2240	N-2230	3"	40	3.068	0.018	6	1	3.6	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	9.6
C-1051 Subheader #5	S-2245	N-2250	N-2170	8"	40	7.981	0.014	2	0	0.0	0	0.0	0	0.0	0	0.0	1	39.9	0	0.0	41.9
C-1051 Subheader #6	S-2255	N-2260	N-2250	6"	40	6.065	0.015	19	1	7.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	26.1
PSV-1051 NEW to Subheader	S-2265	N-2270	N-2260	3"	40	3.068	0.018	4	1	3.6	0	0.0	0	0.0	0	0.0	1	15.3	0	0.0	22.9
PSV-1051C to Subheader	S-2275	N-2280	N-2260	6"	40	6.065	0.015	38	2	14.2	0	0.0	0	0.0	1	10.1	0	0.0	0	0.0	62.3

Targa Resources LLC
Valley Wells Compressor Station
External Fire Zone #1 - C-1051 and C-1052
Flare Knockout Drum Evaluation

Inputs		
Density (Liquid)	40.00	lb/ft ³
Total Liquid In Flow	0	BPD
Low Liquid Level	7%	
Normal Liquid Level	14%	
High Liquid Level	30%	
Minimum Droplet Size	147	microns
Vessel Inner Diameter	6	ft
Selected Vessel Length	20	ft
Results from Hydraulic Evaluation		
Vapor Flowrate	7.03	MMSCFD
Operating Temperature	499.40	F
Operating Pressure	2.15	psig
Atmospheric Pressure	14.7	psia
MW (Vapor)	49.65	
Viscosity (Vapor)	0.01	cp
Density (Vapor)	0.082	lb/ft ³
Mass Flowrate	10.7	lb/s
Volumetric Flowrate	130.0	ft ³ /sec
Calculate Terminal Settling Velocity		
Minimum Droplet Size	0.000482	ft
c'(Re)^2	347.5	
Drag Coefficient C'	4.33	
Terminal Settling Velocity	1.53	ft/s
Calculate Vessel Nozzle Separation Based on Low Level		
Full Area	28.3	ft ²
Required Fall Distance	5.6	ft
Required Residence Time	3.7	sec
Gas Velocity	4.60	ft/sec
Min. Nozzle Separation	16.8	ft
Calculate Vessel Nozzle Separation Based on Normal Level		
Level	0.8	ft
Required Fall Distance	5.2	ft
Required Residence Time	3.4	sec
α	43.9	degrees
x	2.1	ft
Circular Area	21.4	ft ²
Triangle Area	4.5	ft ²
Cross-Sectional Area	25.9	ft ²
Gas Velocity	5.02	ft/sec
Min. Nozzle Separation	17.0	ft
Calculate Vessel Nozzle Separation Based on High Level		
Level	1.8	ft
Required Fall Distance	4.2	ft
Required Residence Time	2.8	sec
α	66.4	degrees
x	2.7	ft
Circular Area	17.8	ft ²
Triangle Area	3.3	ft ²
Cross-Sectional Area	21.1	ft ²
Gas Velocity	6.15	ft/sec
Min. Nozzle Separation	16.9	ft

Targa Resources LLC
Valley Wells Compressor Station
External Fire Zone #1 - C-1051 and C-1052
Flare Tip Radiation and Exit Velocity


Inputs

Atmospheric Pressure	P_{atm}	14.7	psia
Mass Flowrate	q_m	38,319	lb/hr
Temperature	T_j	499	F
Molecular Weight	M_j	49.65	lb/lbmole
Compressibility	Z_j	0.99	
Heat of Combustion	LHV	19,318	Btu/lb
Flare Inner Diameter	d_j	1.17	ft
Flare Height	h	100	ft
Fraction Heat Radiated	F	0.16	
Wind Speed	u_j	20	mph
Ambient Temperature	T_∞	60	F
Horizontal Distance to Flame Center	x_c	15	ft
Vertical Distance to Flame Center	y_c	12	ft


Outputs

Exit Mach Number	Ma_2	0.14	
Isothermal Sonic Velocity	u_s	980.3	ft/sec
Exit Velocity	u_j	139.8	ft/sec
Mixture LEL	C_L	3.34	vol %
Wind Speed	u_j	29.3	ft/sec
LEL Concentration Parameter	C_L	0.273	
Jet and Wind Thrust	$d_j R$	28.8	
Heat Released	Q	740	MMBtu/hr
Flame Center Height	h'	112	ft

Radiation Level	Distance from Base d_b (ft)	Distance from Center d_c (ft)
200	201	217
300	152	177
400	120	154
500	94	137
600	71	125
700	45	116
800	N/A	109
900	N/A	102
1,000	N/A	97
1,100	N/A	93
1,200	N/A	89
1,300	N/A	85
1,400	N/A	82
1,500	N/A	79
1,600	N/A	77
1,700	N/A	74
1,800	N/A	72
1,900	N/A	70
2,000	N/A	69
2,100	N/A	67
2,200	N/A	65
2,300	N/A	64
2,350	N/A	63
2,450	N/A	62
2,550	N/A	61



Radiation Versus Distance from Base of Stack External Fire Zone 1 - C-1051 & 1052




**Targa Resources LLC
Valley Wells Compressor Station
External Fire Zone #1 - C-1051 and C-1052
Flare Gas LEL Calculation**

Component	LEL (Vol %)	Gross Heating Value (Btu/scf)	Net Heating Value (Btu/scf)	MW	Mole Fraction	LEL Contribution (%)	HHV Contribution (Btu/scf)	LHV Contribution (Btu/scf)
Hydrogen Sulfide	4.3	1,573.4	1,450.6	34.08	0.0002	0.00082	0.3	0.3
Nitrogen	100.0	-	-	28.01	0.0014	0.14315	0.0	0.0
Methane	5.0	1,010.0	909.4	16.04	0.3979	1.98964	401.9	361.9
Carbon Dioxide	100.0	-	-	44.01	0.0020	0.19742	0.0	0.0
Ethane	3.0	1,769.7	1,618.7	30.07	0.1212	0.36357	214.5	196.2
Propane	2.1	2,516.2	2,314.9	44.10	0.0878	0.18437	220.9	203.2
Butane	1.6	3,262.4	3,010.8	58.12	0.0550	0.08801	179.4	165.6
Isobutane	1.6	3,252.0	3,000.4	58.12	0.0197	0.03159	64.2	59.2
Pentane	1.4	4,008.7	3,706.9	72.15	0.0315	0.04403	126.1	116.6
Isopentane	1.3	4,000.9	3,699.0	72.15	0.0223	0.02903	89.3	82.6
Hexane	1.1	4,756.0	4,403.8	86.18	0.0198	0.02175	94.1	87.1
Cyclohexane	1.3	4,443.5	4,144.6	84.16	0.0169	0.02195	75.0	70.0
Heptane	1.1	5,502.5	5,100.0	100.20	0.0099	0.01088	54.4	50.4
Octane	1.0	6,248.9	5,796.0	114.23	0.1010	0.10098	631.0	585.3
Benzene	1.2	3,741.9	3,590.9	78.11	0.0107	0.01288	40.2	38.6
Ethylbenzene	1.0	5,222.0	4,970.4	106.17	0.1027	0.10270	536.3	510.4
					1.0000	3.34276	2,728	2,527

Mixture MW 49.65 lb/lbmole
Mixture LEL 3.34 Vol %
Mixture HHV 2,728 Btu/scf
Mixture HHV 20,849 Btu/lbm
Mixture LHV 2,527 Btu/scf
Mixture LHV 19,318 Btu/lbm

API Standard 521 / ISO 23251



Key

- X \bar{C}_L , the lower-explosive-limit concentration parameter for the flare gas, see Equation (C.7)
- Y y_c , vertical distance from the stack to flame centre, expressed in feet
- ^a $(d_j R)$ is the parameter for jet thrust and wind thrust, see Equation (C.8).

Figure C.5 — Flame centre for flares and ignited vents — Vertical distance, y_c (USC units)

C.3.4 Calculation of the distance from the flame centre to the object or point being considered

The design basis for this calculation is as follows: The fraction of heat radiated, F , is 0,3. The heat liberated (see C.2.3), Q , is $6,3 \times 10^6$ kW ($2,15 \times 10^{10}$ Btu/h). Say the flare stack design must limit the maximum allowable radiation (see 6.4.2.3), K , is $9,5$ kW/m² (3 000 Btu/h·ft²).

In Equation (24), the value of τ should be assumed to be 1,0 (see C.3.6.3 and C.3.6.4). The distance from the flame centre to the object or point being considered (that is, the distance to the limit of the radiant heat intensity, such as grade level, an equipment platform, or a plant boundary), D , is then calculated as follows:


$$D = \sqrt{\frac{\tau \cdot F \cdot Q}{4\pi \cdot K}} \tag{24}$$

In SI units:

$$D = \sqrt{\frac{1,0 \times 0,3 \times 6,3 \times 10^6}{4\pi \times 9,5}} = 126 \text{ m}$$

Targa Resources LLC
 Valley Wells Compressor Station
 External Fire Zone #1 - C-1051 and C-1052
 Horizontal Distance to Flame Center - API STD 521 Figure C-5

API Standard 521 / ISO 23251



Key

X \bar{C}_L , the lower-explosive-limit concentration parameter for the flare gas, see Equation (C.7)

Y x_c , horizontal distance from the stack to flame centre, expressed in feet

^a $(d_j R)$ is the parameter for jet thrust and wind thrust, see Equation (C.8).

Figure C.3 — Flame centre for flares and ignited vents — Horizontal distance, x_c (USC units)



Equipment Data:

Equipment Tag:	V-9410 (C-1051)	Type:	Pressure Vessel
Drawing:	D-2415-F-03A	MAWP:	250 psig
Description:	C-1051 1st Stage Suction Scrubber	MAWT:	150 F

Scenario Description:

The scrubber may contain hydrocarbon liquids that condense out of the inlet stream. As such, overpressure could occur in the event of an external fire due to vaporization of the liquid. As the simulation predicts liquid drop out at the facility inlet, the hydrocarbon liquid composition was determined by dropping the inlet temperature to 70 F at which point a small amount of liquid hydrocarbon drops out. The liquid level was based on the LSHH location which is 19" or 19%.

Scenario Calculation Results:

Required Rate:	8910 lb/hr	Device Choke Pressure:	205.8 psig
Actual Capacity:	46052.9 lb/hr	Outlet Temperature:	455.4 F
Required Area:	0.249 in2	Outlet Mass Quality:	1.000
Actual Area:	1.287 in2	Outlet Density:	0.133 lb/ft3
Relief Pressure:	326.7 psig	Outlet Ideal Cp/Cv:	1.042
Relief Temperature:	497.3 F	Outlet Viscosity:	0.011 cP
Relief MW:	89.34	Inlet Non-Recoverble dP:	6.3 psi
Relief Mass Quality:	1.000	Inlet dP % Set:	2.3 % Set
Relief Density:	4.53 lb/ft3	Built-Up Back Pressure:	64.5 psig
Relief SG:	3.081	Built-Up Back P % Set:	23.9 % Set
Relief Z:	0.66	Total Back Pressure:	64.5 psig
Relief Ideal Cp/Cv:	1.04	Total Back P % Set:	23.9 % Set
Relief Viscosity:	0.011 cP		



Equipment Data:

Equipment Tag:	V-9410 (C-1051)	Type:	Pressure Vessel
Drawing:	D-2415-F-03A	MAWP:	250 psig
Description:	C-1051 1st Stage Suction Scrubber	MAWT:	150 F

Scenario Input Data:

Length: in

Diameter: in

Orientation:

Head Type:

Level Basis:

Additional Wetted Area: ft²

Level:

Bottom Elevation: ft

Area Exponent:

Adequate Drainage:

Insulation Factor:

Start Mass % Vapor:

Finish Mass % Vapor:

Remove Sensible Heat: Correct for Densities:

Set Pressure: psig

Allowable Overpressure:

Constant Back Pressure: psig

Use Thermodynamics:

Thermo Package:

Relief Device Kd:

Nozzle Sizing:

Outlet Pipe Sizing:

Scenario Output Data:

Wetted Area:	<input type="text" value="26.6"/>	ft ²
Fire Heat Input:	<input type="text" value="0.51"/>	MMBtu/hr
Total Heat/lb Vaporized:	<input type="text" value="254.0"/>	Btu/lb
Sensible Heat/lb Vaporized:	<input type="text" value="196.9"/>	Btu/lb
Latent Heat:	<input type="text" value="57.1"/>	Btu/lb
Initial Relief Temperature:	<input type="text" value="485.3"/>	F
Temp. at Start Quality:	<input type="text" value="485.3"/>	F
Cp at Start Quality:	<input type="text" value="0.811"/>	Btu/lb/F
Cp at Final Quality:	<input type="text" value="0.829"/>	Btu/lb/F
Liquid Density:	<input type="text" value="31.49"/>	lb/ft ³
Required Mass Rate:	<input type="text" value="8910.0"/>	lb/hr
Required Std. Vol. Rate:	<input type="text" value="0.91"/>	MMSCFD
Required Air Rate:	<input type="text" value="90133.8"/>	scfh air
Relief Mass Flux:	<input type="text" value="1430.7"/>	lb/sec/ft ²

Notes:



Equipment Data:

Equipment Tag:	V-9410 (C-1051)	Type:	Pressure Vessel
Drawing:	D-2415-F-03A	MAWP:	250 psig
Description:	C-1051 1st Stage Suction Scrubber	MAWT:	150 F

Liquid Stream Description: Valley Wells Compressor Scrubber Liquids

Relief Stream Description: V-9410 Fire HC Vapor

Component	Liquid Stream Mole Fraction	Relief Stream Mole Fraction
hydrogen sulfide	0.0000	0.0000
nitrogen	0.0000	0.0000
methane	0.0100	0.0516
carbon dioxide	0.0001	0.0005
ethane	0.0114	0.0430
propane	0.0169	0.0506
butane	0.0231	0.0522
isobutane	0.0067	0.0162
ipentane	0.0238	0.0433
isopentane	0.0158	0.0288
hexane	0.0286	0.0382
cyclohexane	0.0316	0.0359
heptane	0.0233	0.0241
octane	0.3616	0.2889
benzene	0.0183	0.0222
ethylbenzene	0.4287	0.3045



Equipment Data:

Equipment Tag:	V-9432 (C-1051)	Type:	Pressure Vessel
Drawing:	D-2415-F-03C	MAWP:	1450 psig
Description:	C-1051 3rd Stage Discharge Bottle	MAWT:	350 F

Scenario Description:

The 3rd Stage Discharge Bottle is free of liquid therefore overpressure could occur due to expansion of the vapor in the during an external fire. The required relief rate was based on the 3rd stage discharge PSHH setting of 1300 psig and 260 F with a relief pressure of 1742.4 psig.

Scenario Calculation Results:

Required Rate:	1428.4	lb/hr	Device Choke Pressure:	989.4	psig
Actual Capacity:	65863.4	lb/hr	Outlet Temperature:	393.8	F
Required Area:	0.019	in ²	Outlet Mass Quality:	1.000	
Actual Area:	0.865	in ²	Outlet Density:	0.034	lb/ft ³
Relief Pressure:	1742.4	psig	Outlet Ideal Cp/Cv:	1.2	
Relief Temperature:	435.0	F	Outlet Viscosity:	0.015	cP
Relief MW:	21.78		Inlet Non-Recoverble dP:	11.6	psi
Relief Mass Quality:	1.000		Inlet dP % Set:	0.8	% Set
Relief Density:	4.13	lb/ft ³	Built-Up Back Pressure:	159.3	psig
Relief SG:	0.751		Built-Up Back P % Set:	11.1	% Set
Relief Z:	0.97		Total Back Pressure:	159.3	psig
Relief Ideal Cp/Cv:	1.17		Total Back P % Set:	11.1	% Set
Relief Viscosity:	0.016	cP			



Equipment Data:

Equipment Tag:	V-9432 (C-1051)	Type:	Pressure Vessel
Drawing:	D-2415-F-03C	MAWP:	1450 psig
Description:	C-1051 3rd Stage Discharge Bottle	MAWT:	350 F

Scenario Input Data:

Length:	<input type="text" value="74"/> in
Diameter:	<input type="text" value="20"/> in
Orientation:	<input type="text" value="Horizontal"/>
Head Type:	<input type="text" value="2:1 Ellipsoidal"/>
Additional Area:	<input type="text" value="0"/> ft2
Maximum Wall Temp.:	<input type="text" value="1100"/> F
Set Pressure:	<input type="text" value="1440"/> psig
Allowable Overpressure:	<input type="text" value="21.0%"/>
Constant Back Pressure:	<input type="text" value="0.0"/> psig
Operating Pressure:	<input type="text" value="1300"/> psig
Operating Temperature:	<input type="text" value="260"/> F
Thermodynamics Enabled:	<input checked="" type="checkbox"/>
Initial Relief T per Ideal Gas:	<input type="checkbox"/>
Thermo Package:	<input type="text" value="Advanced_Peng-Robinson"/>
Relief Device Kd:	<input type="text" value="0.818"/>
Nozzle Sizing:	<input type="text" value="API 520 Vapor"/>
Outlet Pipe Sizing:	<input type="text" value="Isothermal"/>

Scenario Output Data:

Exposed Area:	<input type="text" value="38"/> ft2
Required Mass Rate:	<input type="text" value="1428.4"/> lb/hr
Required Rate Std. Vol.:	<input type="text" value="0.60"/> MMSCFD
Required Air Rate:	<input type="text" value="28297.6"/> scfh air
Required Mass Flux:	<input type="text" value="3045.7"/> lb/sec/ft2

Notes:



Equipment Data:

Equipment Tag:	V-9432 (C-1051)	Type:	Pressure Vessel
Drawing:	D-2415-F-03C	MAWP:	1450 psig
Description:	C-1051 3rd Stage Discharge Bottle	MAWT:	350 F

Relief Stream Composition:

Stream Description: Valley Wells 3rd Suction Gas

Component	Mole Fraction
hydrogen sulfide	0.0003
nitrogen	0.0016
methane	0.7626
carbon dioxide	0.0027
ethane	0.1316
propane	0.0578
butane	0.0193
isobutane	0.0084
ipentane	0.0053
isopentane	0.0047
hexane	0.0015
cyclohexane	0.0010
heptane	0.0003
octane	0.0012
benzene	0.0007
ethylbenzene	0.0009



Equipment Data:

Equipment Tag:	V-9422 (C-1051)	Type:	Pressure Vessel
Drawing:	D-2415-F-03B	MAWP:	645 psig
Description:	C-1051 2nd Stage Discharge Bottle	MAWT:	350 F

Scenario Description:

In the event the 3rd Stage Suction Scrubber contains liquid hydrocarbon, overpressure could occur due to the vaporization of the liquid during an external fire. The required relief rate was based on the predicted hydrocarbon liquid composition at the relief pressure of 780.5 psig. The liquid level was based on the location of LSHH-1502 with is 19" or 22%. Note that hydrocarbon represents the worst case so the relief requirement is significantly less if water is only present.

Scenario Calculation Results:

Required Rate:	4627.5 lb/hr	Device Choke Pressure:	447.0 psig
Actual Capacity:	107056.1 lb/hr	Outlet Temperature:	226.6 F
Required Area:	0.090 in2	Outlet Mass Quality:	1.000
Actual Area:	2.074 in2	Outlet Density:	0.068 lb/ft3
Relief Pressure:	780.5 psig	Outlet Ideal Cp/Cv:	1.128
Relief Temperature:	284.0 F	Outlet Viscosity:	0.011 cP
Relief MW:	34.85	Inlet Non-Recoverble dP:	4.6 psi
Relief Mass Quality:	1.000	Inlet dP % Set:	0.7 % Set
Relief Density:	4.32 lb/ft3	Built-Up Back Pressure:	96.5 psig
Relief SG:	1.202	Built-Up Back P % Set:	15.0 % Set
Relief Z:	0.80	Total Back Pressure:	96.5 psig
Relief Ideal Cp/Cv:	1.12	Total Back P % Set:	15.0 % Set
Relief Viscosity:	0.012 cP		



Equipment Data:

Equipment Tag:	V-9422 (C-1051)	Type:	Pressure Vessel
Drawing:	D-2415-F-03B	MAWP:	645 psig
Description:	C-1051 2nd Stage Discharge Bottle	MAWT:	350 F

Scenario Input Data:

Length: in

Diameter: in

Orientation:

Head Type:

Level Basis:

Additional Wetted Area: ft2

Level:

Bottom Elevation: ft

Area Exponent:

Adequate Drainage:

Insulation Factor:

Start Mass % Vapor:

Finish Mass % Vapor:

Remove Sensible Heat: Correct for Densities:

Set Pressure: psig

Allowable Overpressure:

Constant Back Pressure: psig

Use Thermodynamics:

Thermo Package:

Relief Device Kd:

Nozzle Sizing:

Outlet Pipe Sizing:

Scenario Output Data:

Wetted Area:	<input type="text" value="14.2"/>	ft2
Fire Heat Input:	<input type="text" value="0.3"/>	MMBtu/hr
Total Heat/lb Vaporized:	<input type="text" value="1310.0"/>	Btu/lb
Sensible Heat/lb Vaporized:	<input type="text" value="1251.8"/>	Btu/lb
Latent Heat:	<input type="text" value="58.2"/>	Btu/lb
Initial Relief Temperature:	<input type="text" value="184.1"/>	F
Temp. at Start Quality:	<input type="text" value="184.2"/>	F
Cp at Start Quality:	<input type="text" value="0.589"/>	Btu/lb/F
Cp at Final Quality:	<input type="text" value="0.665"/>	Btu/lb/F
Liquid Density:	<input type="text" value="37.24"/>	lb/ft3
Required Mass Rate:	<input type="text" value="4627.5"/>	lb/hr
Required Std. Vol. Rate:	<input type="text" value="1.21"/>	MMSCFD
Required Air Rate:	<input type="text" value="66076.5"/>	scfh air
Relief Mass Flux:	<input type="text" value="2064.7"/>	lb/sec/ft2

Notes:



Equipment Data:

Equipment Tag:	V-9422 (C-1051)	Type:	Pressure Vessel
Drawing:	D-2415-F-03B	MAWP:	645 psig
Description:	C-1051 2nd Stage Discharge Bottle	MAWT:	350 F

Liquid Stream Description: Valley Wells 3rd Scrubber Liquids

Relief Stream Description: V-9422 Fire HC Vapor

Component	Liquid Stream Mole Fraction	Relief Stream Mole Fraction
hydrogen sulfide	0.0001	0.0002
nitrogen	0.0000	0.0000
methane	0.1422	0.4740
carbon dioxide	0.0011	0.0028
ethane	0.0935	0.1807
propane	0.0995	0.1263
butane	0.0872	0.0675
isobutane	0.0292	0.0258
ipentane	0.0574	0.0307
isopentane	0.0428	0.0229
hexane	0.0442	0.0132
cyclohexane	0.0395	0.0094
heptane	0.0206	0.0039
octane	0.1650	0.0201
benzene	0.0237	0.0063
ethylbenzene	0.1540	0.0161



Equipment Data:

Equipment Tag:	V-9412 (C-1051)	Type:	Pressure Vessel
Drawing:	D-2415-F-03A	MAWP:	275 psig
Description:	C-1051 1st Stage Discharge Bottle	MAWT:	350 F

Scenario Description:

In the event the 2nd Stage Suction Scrubber contains liquid hydrocarbon, overpressure could occur due to the vaporization of the liquid during an external fire. The required relief rate was based on the predicted hydrocarbon liquid composition at the relief pressure of 302.5 psig. The liquid level was based on the location of LSHH-1501 with is 19" or 22%. Note that hydrocarbon represents so the relief requirement is significantly less if water is only present.

Scenario Calculation Results:

Required Rate:	3870 lb/hr	Device Choke Pressure:	173.0 psig
Actual Capacity:	97031 lb/hr	Outlet Temperature:	349.9 F
Required Area:	0.163 in2	Outlet Mass Quality:	1.000
Actual Area:	4.080 in2	Outlet Density:	0.094 lb/ft3
Relief Pressure:	302.5 psig	Outlet Ideal Cp/Cv:	1.071
Relief Temperature:	377.3 F	Outlet Viscosity:	0.011 cP
Relief MW:	56.56	Inlet Non-Recoverble dP:	2.3 psi
Relief Mass Quality:	1.000	Inlet dP % Set:	0.9 % Set
Relief Density:	2.38 lb/ft3	Built-Up Back Pressure:	40.3 psig
Relief SG:	1.950	Built-Up Back P % Set:	16.1 % Set
Relief Z:	0.84	Total Back Pressure:	40.3 psig
Relief Ideal Cp/Cv:	1.07	Total Back P % Set:	16.1 % Set
Relief Viscosity:	0.012 cP		



Equipment Data:

Equipment Tag:	V-9412 (C-1051)	Type:	Pressure Vessel
Drawing:	D-2415-F-03A	MAWP:	275 psig
Description:	C-1051 1st Stage Discharge Bottle	MAWT:	350 F

Scenario Input Data:

Length: in

Diameter: in

Orientation:

Head Type:

Level Basis:

Additional Wetted Area: ft²

Level:

Bottom Elevation: ft

Area Exponent:

Adequate Drainage:

Insulation Factor:

Start Mass % Vapor:

Finish Mass % Vapor:

Remove Sensible Heat: Correct for Densities:

Set Pressure: psig

Allowable Overpressure:

Constant Back Pressure: psig

Use Thermodynamics:

Thermo Package:

Relief Device Kd:

Nozzle Sizing:

Outlet Pipe Sizing:

Scenario Output Data:

Wetted Area:	<input type="text" value="16.1"/>	ft ²
Fire Heat Input:	<input type="text" value="0.34"/>	MMBtu/hr
Total Heat/lb Vaporized:	<input type="text" value="1550.0"/>	Btu/lb
Sensible Heat/lb Vaporized:	<input type="text" value="1468.2"/>	Btu/lb
Latent Heat:	<input type="text" value="81.8"/>	Btu/lb
Initial Relief Temperature:	<input type="text" value="260.4"/>	F
Temp. at Start Quality:	<input type="text" value="260.6"/>	F
Cp at Start Quality:	<input type="text" value="0.586"/>	Btu/lb/F
Cp at Final Quality:	<input type="text" value="0.672"/>	Btu/lb/F
Liquid Density:	<input type="text" value="40.50"/>	lb/ft ³
Required Mass Rate:	<input type="text" value="3870.0"/>	lb/hr
Required Std. Vol. Rate:	<input type="text" value="0.62"/>	MMSCFD
Required Air Rate:	<input type="text" value="46016.3"/>	scfh air
Relief Mass Flux:	<input type="text" value="951.3"/>	lb/sec/ft ²

Notes:



Equipment Data:

Equipment Tag:	V-9412 (C-1051)	Type:	Pressure Vessel
Drawing:	D-2415-F-03A	MAWP:	275 psig
Description:	C-1051 1st Stage Discharge Bottle	MAWT:	350 F

Liquid Stream Description: Valley Wells 2nd Scrubber Liquids

Relief Stream Description: V-9420 Fire HC Vapor

Component	Liquid Stream Mole Fraction	Relief Stream Mole Fraction
hydrogen sulfide	0.0001	0.0004
nitrogen	0.0000	0.0000
methane	0.0400	0.2484
carbon dioxide	0.0004	0.0021
ethane	0.0331	0.1377
propane	0.0404	0.1207
butane	0.0433	0.0846
isobutane	0.0136	0.0296
ipentane	0.0356	0.0496
isopentane	0.0251	0.0350
hexane	0.0346	0.0288
cyclohexane	0.0364	0.0237
heptane	0.0234	0.0127
octane	0.3061	0.1083
benzene	0.0212	0.0153
ethylbenzene	0.3468	0.1031



Equipment Data:

Equipment Tag:	F-3052 (C-1051)	Type:	Pressure Vessel
Drawing:	D-2415-F-03F	MAWP:	270 psig
Description:	C-1051 Fuel Gas Filter	MAWT:	150 F

Scenario Description:

As no liquids are expected in the Fuel Gas Filter, an external fire could result in overpressure due expansion of the vapor. The normal fuel gas supply pressure is 135 psig with a proposed PAHH-2022 set point of 150 psig on the 2nd Stage Fuel Gas Scrubber (V-2020). The required relief rate was therefore conservatively based on operating conditions of 150 psig and 60 F with the relief pressure of 211.75 psig. The normal Whistler Fuel Gas composition was used.

Scenario Calculation Results:

Required Rate:	323.7	lb/hr	Device Choke Pressure:	110.8	psig
Actual Capacity:	2035.3	lb/hr	Outlet Temperature:	236.5	F
Required Area:	0.034	in ²	Outlet Mass Quality:	1.000	
Actual Area:	0.212	in ²	Outlet Density:	0.032	lb/ft ³
Relief Pressure:	211.8	psig	Outlet Ideal Cp/Cv:	1.3	
Relief Temperature:	244.0	F	Outlet Viscosity:	0.014	cP
Relief MW:	16.67		Inlet Non-Recoverble dP:	1.1	psi
Relief Mass Quality:	1.000		Inlet dP % Set:	0.6	% Set
Relief Density:	0.51	lb/ft ³	Built-Up Back Pressure:	42.5	psig
Relief SG:	0.575		Built-Up Back P % Set:	24.3	% Set
Relief Z:	0.99		Total Back Pressure:	42.5	psig
Relief Ideal Cp/Cv:	1.26		Total Back P % Set:	24.3	% Set
Relief Viscosity:	0.014	cP			



Equipment Data:

Equipment Tag:	F-3052 (C-1051)	Type:	Pressure Vessel
Drawing:	D-2415-F-03F	MAWP:	270 psig
Description:	C-1051 Fuel Gas Filter	MAWT:	150 F

Scenario Input Data:

Length:	75.375	in
Diameter:	8.625	in
Orientation:	Vertical	
Head Type:	2:1 Ellipsoidal	
Additional Area:	0	ft2
Maximum Wall Temp.:	1100	F
Set Pressure:	175	psig
Allowable Overpressure:	21.0%	
Constant Back Pressure:	0.0	psig
Operating Pressure:	150	psig
Operating Temperature:	60	F
Thermodynamics Enabled:	<input checked="" type="checkbox"/>	
Initial Relief T per Ideal Gas:	<input type="checkbox"/>	
Thermo Package:	Advanced_Peng-Robinson	
Relief Device Kd:	0.800	
Nozzle Sizing:	API 520 Vapor	
Outlet Pipe Sizing:	Isothermal	

Scenario Output Data:

Exposed Area:	15	ft2
Required Mass Rate:	323.7	lb/hr
Required Rate Std. Vol.:	0.18	MMSCFD
Required Air Rate:	6500.4	scfh air
Required Mass Flux:	384.0	lb/sec/ft2

Notes:



Equipment Data:

Equipment Tag:	F-3052 (C-1051)	Type:	Pressure Vessel
Drawing:	D-2415-F-03F	MAWP:	270 psig
Description:	C-1051 Fuel Gas Filter	MAWT:	150 F

Relief Stream Composition:

Stream Description: Valley Wells Whistler Fuel Gas

Component	Mole Fraction
carbon dioxide	0.0010
nitrogen	0.0231
methane	0.9535
ethane	0.0220
propane	0.0004
isobutane	0.0000
butane	0.0000
isopentane	
pentane	
hexane	
heptane	
octane	
nonane	
decane	
methanol	
water	



Equipment Data:

Equipment Tag:	V-9410 (C-1052)	Type:	Pressure Vessel
Drawing:	D-2415-F-04A	MAWP:	270 psig
Description:	C-1052 1st Stage Suction Scrubber	MAWT:	150 F

Scenario Description:

The scrubber may contain hydrocarbon liquids that condense out of the inlet stream. As such, overpressure could occur in the event of an external fire due to vaporization of the liquid. As the simulation predicts liquid drop out at the facility inlet, the hydrocarbon liquid composition was determined by dropping the inlet temperature to 70 F at which point a small amount of liquid hydrocarbon drops out. The liquid level was based on the LSHH location which is 19" or 19%.

Scenario Calculation Results:

Required Rate:	8910	lb/hr	Device Choke Pressure:	205.8	psig
Actual Capacity:	46052.9	lb/hr	Outlet Temperature:	455.4	F
Required Area:	0.249	in2	Outlet Mass Quality:	1.000	
Actual Area:	1.287	in2	Outlet Density:	0.133	lb/ft3
Relief Pressure:	326.7	psig	Outlet Ideal Cp/Cv:	1.042	
Relief Temperature:	497.3	F	Outlet Viscosity:	0.011	cP
Relief MW:	89.34		Inlet Non-Recoverble dP:	6.3	psi
Relief Mass Quality:	1.000		Inlet dP % Set:	2.3	% Set
Relief Density:	4.53	lb/ft3	Built-Up Back Pressure:	64.5	psig
Relief SG:	3.081		Built-Up Back P % Set:	23.9	% Set
Relief Z:	0.66		Total Back Pressure:	64.5	psig
Relief Ideal Cp/Cv:	1.04		Total Back P % Set:	23.9	% Set
Relief Viscosity:	0.011	cP			



Equipment Data:

Equipment Tag:	V-9410 (C-1052)	Type:	Pressure Vessel
Drawing:	D-2415-F-04A	MAWP:	270 psig
Description:	C-1052 1st Stage Suction Scrubber	MAWT:	150 F

Scenario Input Data:

Length: in

Diameter: in

Orientation:

Head Type:

Level Basis:

Additional Wetted Area: ft²

Level:

Bottom Elevation: ft

Area Exponent:

Adequate Drainage:

Insulation Factor:

Start Mass % Vapor:

Finish Mass % Vapor:

Remove Sensible Heat: Correct for Densities:

Set Pressure: psig

Allowable Overpressure:

Constant Back Pressure: psig

Use Thermodynamics:

Thermo Package:

Relief Device Kd:

Nozzle Sizing:

Outlet Pipe Sizing:

Scenario Output Data:

Wetted Area:	<input type="text" value="26.6"/>	ft ²
Fire Heat Input:	<input type="text" value="0.51"/>	MMBtu/hr
Total Heat/lb Vaporized:	<input type="text" value="254.0"/>	Btu/lb
Sensible Heat/lb Vaporized:	<input type="text" value="196.9"/>	Btu/lb
Latent Heat:	<input type="text" value="57.1"/>	Btu/lb
Initial Relief Temperature:	<input type="text" value="485.3"/>	F
Temp. at Start Quality:	<input type="text" value="485.3"/>	F
Cp at Start Quality:	<input type="text" value="0.811"/>	Btu/lb/F
Cp at Final Quality:	<input type="text" value="0.829"/>	Btu/lb/F
Liquid Density:	<input type="text" value="31.49"/>	lb/ft ³
Required Mass Rate:	<input type="text" value="8910.0"/>	lb/hr
Required Std. Vol. Rate:	<input type="text" value="0.91"/>	MMSCFD
Required Air Rate:	<input type="text" value="90133.8"/>	scfh air
Relief Mass Flux:	<input type="text" value="1430.7"/>	lb/sec/ft ²

Notes:



Equipment Data:

Equipment Tag:	V-9410 (C-1052)	Type:	Pressure Vessel
Drawing:	D-2415-F-04A	MAWP:	270 psig
Description:	C-1052 1st Stage Suction Scrubber	MAWT:	150 F

Liquid Stream Description: Valley Wells Compressor Scrubber Liquids

Relief Stream Description: V-9410 Fire HC Vapor

Component	Liquid Stream Mole Fraction	Relief Stream Mole Fraction
hydrogen sulfide	0.0000	0.0000
nitrogen	0.0000	0.0000
methane	0.0100	0.0516
carbon dioxide	0.0001	0.0005
ethane	0.0114	0.0430
propane	0.0169	0.0506
butane	0.0231	0.0522
isobutane	0.0067	0.0162
ipentane	0.0238	0.0433
isopentane	0.0158	0.0288
hexane	0.0286	0.0382
cyclohexane	0.0316	0.0359
heptane	0.0233	0.0241
octane	0.3616	0.2889
benzene	0.0183	0.0222
ethylbenzene	0.4287	0.3045



Equipment Data:

Equipment Tag:	V-9432 (C-1052)	Type:	Pressure Vessel
Drawing:	D-2415-F-04C	MAWP:	1450 psig
Description:	C-1052 3rd Stage Discharge Bottle	MAWT:	350 F

Scenario Description:

The 3rd Stage Discharge Bottle is free of liquid therefore overpressure could occur due to expansion of the vapor in the during an external fire. The required relief rate was based on the 3rd stage discharge PSHH setting of 1300 psig and 260 F with a relief pressure of 1742.4 psig.

Scenario Calculation Results:

Required Rate:	1428.4	lb/hr	Device Choke Pressure:	989.4	psig
Actual Capacity:	65863.4	lb/hr	Outlet Temperature:	393.8	F
Required Area:	0.019	in ²	Outlet Mass Quality:	1.000	
Actual Area:	0.865	in ²	Outlet Density:	0.034	lb/ft ³
Relief Pressure:	1742.4	psig	Outlet Ideal Cp/Cv:	1.2	
Relief Temperature:	435.0	F	Outlet Viscosity:	0.015	cP
Relief MW:	21.78		Inlet Non-Recoverble dP:	11.6	psi
Relief Mass Quality:	1.000		Inlet dP % Set:	0.8	% Set
Relief Density:	4.13	lb/ft ³	Built-Up Back Pressure:	159.3	psig
Relief SG:	0.751		Built-Up Back P % Set:	11.1	% Set
Relief Z:	0.97		Total Back Pressure:	159.3	psig
Relief Ideal Cp/Cv:	1.17		Total Back P % Set:	11.1	% Set
Relief Viscosity:	0.016	cP			



Equipment Data:

Equipment Tag:	V-9432 (C-1052)	Type:	Pressure Vessel
Drawing:	D-2415-F-04C	MAWP:	1450 psig
Description:	C-1052 3rd Stage Discharge Bottle	MAWT:	350 F

Scenario Input Data:

Length:	74	in
Diameter:	20	in
Orientation:	Horizontal	
Head Type:	2:1 Ellipsoidal	
Additional Area:	0	ft2
Maximum Wall Temp.:	1100	F
Set Pressure:	1440	psig
Allowable Overpressure:	21.0%	
Constant Back Pressure:	0.0	psig
Operating Pressure:	1300	psig
Operating Temperature:	260	F
Thermodynamics Enabled:	<input checked="" type="checkbox"/>	
Initial Relief T per Ideal Gas:	<input type="checkbox"/>	
Thermo Package:	Advanced_Peng-Robinson	
Relief Device Kd:	0.818	
Nozzle Sizing:	API 520 Vapor	
Outlet Pipe Sizing:	Isothermal	

Scenario Output Data:

Exposed Area:	38	ft2
Required Mass Rate:	1428.4	lb/hr
Required Rate Std. Vol.:	0.60	MMSCFD
Required Air Rate:	28297.6	scfh air
Required Mass Flux:	3045.7	lb/sec/ft2

Notes:



Equipment Data:

Equipment Tag:	V-9432 (C-1052)	Type:	Pressure Vessel
Drawing:	D-2415-F-04C	MAWP:	1450 psig
Description:	C-1052 3rd Stage Discharge Bottle	MAWT:	350 F

Relief Stream Composition:

Stream Description: Valley Wells 3rd Suction Gas

Component	Mole Fraction
hydrogen sulfide	0.0003
nitrogen	0.0016
methane	0.7626
carbon dioxide	0.0027
ethane	0.1316
propane	0.0578
butane	0.0193
isobutane	0.0084
ipentane	0.0053
isopentane	0.0047
hexane	0.0015
cyclohexane	0.0010
heptane	0.0003
octane	0.0012
benzene	0.0007
ethylbenzene	0.0009



Equipment Data:

Equipment Tag:	V-9422 (C-1052)	Type:	Pressure Vessel
Drawing:	D-2415-F-04B	MAWP:	645 psig
Description:	C-1052 2nd Stage Discharge Bottle	MAWT:	350 F

Scenario Description:

In the event the 3rd Stage Suction Scrubber contains liquid hydrocarbon, overpressure could occur due to the vaporization of the liquid during an external fire. The required relief rate was based on the predicted hydrocarbon liquid composition at the relief pressure of 780.5 psig. The liquid level was based on the location of LSHH-1502 with is 19" or 22%. Note that hydrocarbon represents the worst case so the relief requirement is significantly less if water is only present.

Scenario Calculation Results:

Required Rate:	4627.5 lb/hr	Device Choke Pressure:	447.0 psig
Actual Capacity:	107056.1 lb/hr	Outlet Temperature:	226.6 F
Required Area:	0.090 in2	Outlet Mass Quality:	1.000
Actual Area:	2.074 in2	Outlet Density:	0.068 lb/ft3
Relief Pressure:	780.5 psig	Outlet Ideal Cp/Cv:	1.128
Relief Temperature:	284.0 F	Outlet Viscosity:	0.011 cP
Relief MW:	34.85	Inlet Non-Recoverble dP:	4.6 psi
Relief Mass Quality:	1.000	Inlet dP % Set:	0.7 % Set
Relief Density:	4.32 lb/ft3	Built-Up Back Pressure:	96.5 psig
Relief SG:	1.202	Built-Up Back P % Set:	15.0 % Set
Relief Z:	0.80	Total Back Pressure:	96.5 psig
Relief Ideal Cp/Cv:	1.12	Total Back P % Set:	15.0 % Set
Relief Viscosity:	0.012 cP		



Equipment Data:

Equipment Tag:	V-9422 (C-1052)	Type:	Pressure Vessel
Drawing:	D-2415-F-04B	MAWP:	645 psig
Description:	C-1052 2nd Stage Discharge Bottle	MAWT:	350 F

Scenario Input Data:

Length: in

Diameter: in

Orientation:

Head Type:

Level Basis:

Additional Wetted Area: ft2

Level:

Bottom Elevation: ft

Area Exponent:

Adequate Drainage:

Insulation Factor:

Start Mass % Vapor:

Finish Mass % Vapor:

Remove Sensible Heat: Correct for Densities:

Set Pressure: psig

Allowable Overpressure:

Constant Back Pressure: psig

Use Thermodynamics:

Thermo Package:

Relief Device Kd:

Nozzle Sizing:

Outlet Pipe Sizing:

Scenario Output Data:

Wetted Area:	<input type="text" value="14.2"/>	ft2
Fire Heat Input:	<input type="text" value="0.3"/>	MMBtu/hr
Total Heat/lb Vaporized:	<input type="text" value="1310.0"/>	Btu/lb
Sensible Heat/lb Vaporized:	<input type="text" value="1251.8"/>	Btu/lb
Latent Heat:	<input type="text" value="58.2"/>	Btu/lb
Initial Relief Temperature:	<input type="text" value="184.1"/>	F
Temp. at Start Quality:	<input type="text" value="184.2"/>	F
Cp at Start Quality:	<input type="text" value="0.589"/>	Btu/lb/F
Cp at Final Quality:	<input type="text" value="0.665"/>	Btu/lb/F
Liquid Density:	<input type="text" value="37.24"/>	lb/ft3
Required Mass Rate:	<input type="text" value="4627.5"/>	lb/hr
Required Std. Vol. Rate:	<input type="text" value="1.21"/>	MMSCFD
Required Air Rate:	<input type="text" value="66076.5"/>	scfh air
Relief Mass Flux:	<input type="text" value="2064.7"/>	lb/sec/ft2

Notes:



Equipment Data:

Equipment Tag:	V-9422 (C-1052)	Type:	Pressure Vessel
Drawing:	D-2415-F-04B	MAWP:	645 psig
Description:	C-1052 2nd Stage Discharge Bottle	MAWT:	350 F

Liquid Stream Description: Valley Wells 3rd Scrubber Liquids

Relief Stream Description: V-9422 Fire HC Vapor

Component	Liquid Stream Mole Fraction	Relief Stream Mole Fraction
hydrogen sulfide	0.0001	0.0002
nitrogen	0.0000	0.0000
methane	0.1422	0.4740
carbon dioxide	0.0011	0.0028
ethane	0.0935	0.1807
propane	0.0995	0.1263
butane	0.0872	0.0675
isobutane	0.0292	0.0258
ipentane	0.0574	0.0307
isopentane	0.0428	0.0229
hexane	0.0442	0.0132
cyclohexane	0.0395	0.0094
heptane	0.0206	0.0039
octane	0.1650	0.0201
benzene	0.0237	0.0063
ethylbenzene	0.1540	0.0161



Equipment Data:

Equipment Tag:	V-9412 (C-1052)	Type:	Pressure Vessel
Drawing:	D-2415-F-04A	MAWP:	275 psig
Description:	C-1052 1st Stage Discharge Bottle	MAWT:	350 F

Scenario Description:

In the event the 2nd Stage Suction Scrubber contains liquid hydrocarbon, overpressure could occur due to the vaporization of the liquid during an external fire. The required relief rate was based on the predicted hydrocarbon liquid composition at the relief pressure of 302.5 psig. The liquid level was based on the location of LSHH-1501 with is 19" or 22%. Note that hydrocarbon represents so the relief requirement is significantly less if water is only present.

Scenario Calculation Results:

Required Rate:	3870	lb/hr	Device Choke Pressure:	173.0	psig
Actual Capacity:	97031	lb/hr	Outlet Temperature:	349.9	F
Required Area:	0.163	in2	Outlet Mass Quality:	1.000	
Actual Area:	4.080	in2	Outlet Density:	0.094	lb/ft3
Relief Pressure:	302.5	psig	Outlet Ideal Cp/Cv:	1.071	
Relief Temperature:	377.3	F	Outlet Viscosity:	0.011	cP
Relief MW:	56.56		Inlet Non-Recoverble dP:	2.3	psi
Relief Mass Quality:	1.000		Inlet dP % Set:	0.9	% Set
Relief Density:	2.38	lb/ft3	Built-Up Back Pressure:	40.3	psig
Relief SG:	1.950		Built-Up Back P % Set:	16.1	% Set
Relief Z:	0.84		Total Back Pressure:	40.3	psig
Relief Ideal Cp/Cv:	1.07		Total Back P % Set:	16.1	% Set
Relief Viscosity:	0.012	cP			



Equipment Data:

Equipment Tag:	V-9412 (C-1052)	Type:	Pressure Vessel
Drawing:	D-2415-F-04A	MAWP:	275 psig
Description:	C-1052 1st Stage Discharge Bottle	MAWT:	350 F

Scenario Input Data:

Length: in

Diameter: in

Orientation:

Head Type:

Level Basis:

Additional Wetted Area: ft²

Level:

Bottom Elevation: ft

Area Exponent:

Adequate Drainage:

Insulation Factor:

Start Mass % Vapor:

Finish Mass % Vapor:

Remove Sensible Heat: Correct for Densities:

Set Pressure: psig

Allowable Overpressure:

Constant Back Pressure: psig

Use Thermodynamics:

Thermo Package:

Relief Device Kd:

Nozzle Sizing:

Outlet Pipe Sizing:

Scenario Output Data:

Wetted Area:	<input type="text" value="16.1"/>	ft ²
Fire Heat Input:	<input type="text" value="0.34"/>	MMBtu/hr
Total Heat/lb Vaporized:	<input type="text" value="1550.0"/>	Btu/lb
Sensible Heat/lb Vaporized:	<input type="text" value="1468.2"/>	Btu/lb
Latent Heat:	<input type="text" value="81.8"/>	Btu/lb
Initial Relief Temperature:	<input type="text" value="260.4"/>	F
Temp. at Start Quality:	<input type="text" value="260.6"/>	F
Cp at Start Quality:	<input type="text" value="0.586"/>	Btu/lb/F
Cp at Final Quality:	<input type="text" value="0.672"/>	Btu/lb/F
Liquid Density:	<input type="text" value="40.50"/>	lb/ft ³
Required Mass Rate:	<input type="text" value="3870.0"/>	lb/hr
Required Std. Vol. Rate:	<input type="text" value="0.62"/>	MMSCFD
Required Air Rate:	<input type="text" value="46016.3"/>	scfh air
Relief Mass Flux:	<input type="text" value="951.3"/>	lb/sec/ft ²

Notes:



Equipment Data:

Equipment Tag:	V-9412 (C-1052)	Type:	Pressure Vessel
Drawing:	D-2415-F-04A	MAWP:	275 psig
Description:	C-1052 1st Stage Discharge Bottle	MAWT:	350 F

Liquid Stream Description: Valley Wells 2nd Scrubber Liquids

Relief Stream Description: V-9420 Fire HC Vapor

Component	Liquid Stream Mole Fraction	Relief Stream Mole Fraction
hydrogen sulfide	0.0001	0.0004
nitrogen	0.0000	0.0000
methane	0.0400	0.2484
carbon dioxide	0.0004	0.0021
ethane	0.0331	0.1377
propane	0.0404	0.1207
butane	0.0433	0.0846
isobutane	0.0136	0.0296
ipentane	0.0356	0.0496
isopentane	0.0251	0.0350
hexane	0.0346	0.0288
cyclohexane	0.0364	0.0237
heptane	0.0234	0.0127
octane	0.3061	0.1083
benzene	0.0212	0.0153
ethylbenzene	0.3468	0.1031



Equipment Data:

Equipment Tag:	F-3052 (C-1052)	Type:	Pressure Vessel
Drawing:	D-2415-F-04F	MAWP:	270 psig
Description:	C-1052 Fuel Gas Filter	MAWT:	150 F

Scenario Description:

As no liquids are expected in the Fuel Gas Filter, an external fire could result in overpressure due expansion of the vapor. The normal fuel gas supply pressure is 135 psig with a proposed PAHH-2022 set point of 150 psig on the 2nd Stage Fuel Gas Scrubber (V-2020). The required relief rate was therefore conservatively based on operating conditions of 150 psig and 60 F with the relief pressure of 211.75 psig. The normal Whistler Fuel Gas composition was used.

Scenario Calculation Results:

Required Rate:	323.7	lb/hr	Device Choke Pressure:	110.8	psig
Actual Capacity:	2035.3	lb/hr	Outlet Temperature:	236.5	F
Required Area:	0.034	in ²	Outlet Mass Quality:	1.000	
Actual Area:	0.212	in ²	Outlet Density:	0.032	lb/ft ³
Relief Pressure:	211.8	psig	Outlet Ideal Cp/Cv:	1.3	
Relief Temperature:	244.0	F	Outlet Viscosity:	0.014	cP
Relief MW:	16.67		Inlet Non-Recoverble dP:	1.1	psi
Relief Mass Quality:	1.000		Inlet dP % Set:	0.6	% Set
Relief Density:	0.51	lb/ft ³	Built-Up Back Pressure:	42.3	psig
Relief SG:	0.575		Built-Up Back P % Set:	24.2	% Set
Relief Z:	0.99		Total Back Pressure:	42.3	psig
Relief Ideal Cp/Cv:	1.26		Total Back P % Set:	24.2	% Set
Relief Viscosity:	0.014	cP			



Equipment Data:

Equipment Tag:	F-3052 (C-1052)	Type:	Pressure Vessel
Drawing:	D-2415-F-04F	MAWP:	270 psig
Description:	C-1052 Fuel Gas Filter	MAWT:	150 F

Scenario Input Data:

Length:	75.375	in
Diameter:	8.625	in
Orientation:	Vertical	
Head Type:	2:1 Ellipsoidal	
Additional Area:	0	ft2
Maximum Wall Temp.:	1100	F
Set Pressure:	175	psig
Allowable Overpressure:	21.0%	
Constant Back Pressure:	0.0	psig
Operating Pressure:	150	psig
Operating Temperature:	60	F
Thermodynamics Enabled:	<input checked="" type="checkbox"/>	
Initial Relief T per Ideal Gas:	<input type="checkbox"/>	
Thermo Package:	Advanced_Peng-Robinson	
Relief Device Kd:	0.800	
Nozzle Sizing:	API 520 Vapor	
Outlet Pipe Sizing:	Isothermal	

Scenario Output Data:

Exposed Area:	15	ft2
Required Mass Rate:	323.7	lb/hr
Required Rate Std. Vol.:	0.18	MMSCFD
Required Air Rate:	6500.4	scfh air
Required Mass Flux:	384.0	lb/sec/ft2

Notes:



Equipment Data:

Equipment Tag:	F-3052 (C-1052)	Type:	Pressure Vessel
Drawing:	D-2415-F-04F	MAWP:	270 psig
Description:	C-1052 Fuel Gas Filter	MAWT:	150 F

Relief Stream Composition:

Stream Description: Valley Wells Whistler Fuel Gas

Component	Mole Fraction
carbon dioxide	0.0010
nitrogen	0.0231
methane	0.9535
ethane	0.0220
propane	0.0004
isobutane	0.0000
butane	0.0000
isopentane	
pentane	
hexane	
heptane	
octane	
nonane	
decane	
methanol	
water	

APPENDIX E – Fire Zone #2 – Sulfatreat Area Details

Hydraulic Detailed Results

Knockout Drum Detailed Results

Flare Detailed Sizing Results

Relief Load Calculations



Targa Resources LLC
Valley Wells Compressor Station
External Fire Zone #2 - Sulfatreat Area

Client:	Targa Resources LLC		Increments/Seg.	5
Project:	Valley Wells Compressor Station		P Atm	14.7 psia
Project Number:	23-1005		Exit Pressure	2 psig
Date:	Mar-24		Roughness	0.00015 feet
Created by:	Rob Kreder		Friction dP Only	FALSE

Input Data						Calculated Values						Inlet Conditions				Exit Conditions				Results				
Description	Segment	Start Node	End Node	Pipe NPS	Pipe Sch	Pipe ID (inches)	Equivalent Length (ft)	Segment Flow (lb/hr)	Segment Flow (MMSCFD)	Moody f	Fluid MW	P ₁ (psig)	T ₁ (F)	K ₁	ρ ₁ (lb/ft ³)	P ₂ (psig)	T ₂ (F)	K ₂	Z ₂	Segment ΔP (psi)	Max. Velocity (ft/sec)	Sonic Velocity (ft/sec)	Segment Max. Mach Number	Choke P at Segment Exit (psig)
Reducer To Flare Base	S-1005	N-1010	N-1000	12"	STD	12.000	2.0	75,560	31.63	0.013	21.76	2.1	151.7	1.214	0.056	2.0	151.7	1.214	0.056	0.0	477.2	1302.7	0.37	-8.5
KO Drum to Reducer	S-1015	N-1020	N-1010	20"	20	19.250	86.4	75,560	31.63	0.013	21.76	2.2	151.7	1.214	0.056	2.1	151.7	1.214	0.056	0.1	185.4	1302.7	0.14	-12.3
KO Drum	S-1025	N-1030	N-1020	20"	20	19.250	66.8	75,560	31.63	0.013	21.76	2.3	151.7	1.214	0.057	2.2	151.7	1.214	0.056	0.1	185.4	1302.7	0.14	-12.3
V-1917 Tie In to KO Drum	S-1035	N-1040	N-1030	20"	20	19.250	575.4	75,560	31.63	0.013	21.76	3.3	151.8	1.214	0.060	2.3	151.7	1.214	0.057	0.9	182.2	1302.7	0.14	-12.3
V-1912 to V-1917 Tie In	S-1045	N-1050	N-1040	20"	20	19.250	25.0	75,560	31.63	0.013	21.76	3.3	151.8	1.214	0.060	3.3	151.8	1.214	0.060	0.0	173.1	1302.8	0.13	-12.3
Sulfatreat to V-1912 Tie In	S-1055	N-1060	N-1050	20"	20	19.250	65.0	75,560	31.63	0.013	21.76	3.5	151.8	1.214	0.061	3.3	151.8	1.214	0.060	0.1	173.1	1302.8	0.13	-12.3
Sulfatreat Subheader #1	S-3995	N-4000	N-1060	4"	40	4.026	37.7	75,560	31.63	0.016	21.76	110.7	158.7	1.213	0.420	40.1	154.2	1.214	0.183	70.6	1302.8	1.00	40.1	
PSV-1811 to Subheader	S-4005	N-4010	N-4000	2"	80	1.939	26.2	18,890	7.91	0.019	21.76	164.1	162.1	1.212	0.601	110.7	158.7	1.213	0.420	53.4	609.3	1309.6	0.47	43.6
Sulfatreat Subheader #2	S-4015	N-4020	N-4000	4"	40	4.026	16.7	56,670	23.72	0.016	21.76	118.1	159.2	1.213	0.445	110.7	158.7	1.213	0.420	7.4	424.0	1309.6	0.32	25.9
PSV-1812 to Subheader	S-4025	N-4030	N-4020	2"	80	1.939	26.2	18,890	7.91	0.019	21.76	168.6	162.3	1.212	0.617	118.1	159.2	1.213	0.445	50.5	575.0	1310.2	0.44	43.6
Sulfatreat Subheader #3	S-4035	N-4040	N-4020	4"	40	4.026	16.7	37,780	15.81	0.016	21.76	121.0	159.4	1.213	0.455	118.1	159.2	1.213	0.445	2.9	266.8	1310.2	0.20	12.3
PSV-1813 to Subheader	S-4045	N-4050	N-4040	2"	80	1.939	26.2	18,890	7.91	0.019	21.76	170.4	162.5	1.212	0.623	121.0	159.4	1.213	0.455	49.4	562.4	1310.4	0.43	43.5
Sulfatreat Subheader #4	S-4055	N-4060	N-4040	4"	40	4.026	16.7	18,890	7.91	0.017	21.76	121.7	159.4	1.213	0.458	121.0	159.4	1.213	0.455	0.7	130.5	1310.4	0.10	-1.2
PSV-1814 to Subheader	S-4065	N-4070	N-4060	2"	80	1.939	26.2	18,890	7.91	0.019	21.76	170.9	162.5	1.212	0.625	121.7	159.4	1.213	0.458	49.2	558.7	1310.4	0.43	43.5



Targa Resources LLC
Valley Wells Compressor Station
External Fire Zone #2 - Sulfatreat Area

Client:	Targa Resources LLC
Project:	Valley Wells Compressor Station
Project Number:	23-1005
Date:	Mar-24
Created by:	Rob Kreder

Segment Data

Description	Segment	Start Node	End Node	Pipe NPS	Pipe Sch	Pipe ID (inches)	Moody F	Pipe Length (ft)	# 90 Elbows	Eq. Length 90 Elbows	# 45 Elbows	Eq. Length 45 Elbows	Entrances	Eq. Length Entrances	Tee Through	Eq. Length Tee Through	Tee Branch	Eq. Length Tee Branch	Ball Valve	Eq. Length Ball Valve	Equivalent Length (ft)
Reducer To Flare Base	S-1005	N-1010	N-1000	12"	STD	12.000	0.013	2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	2.0
KO Drum to Reducer	S-1015	N-1020	N-1010	20"	20	19.250	0.012	19	3	67.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	86.4
KO Drum	S-1025	N-1030	N-1020	20"	20	19.250	0.012	0	0	0.0	0	0.0	1	66.8	0	0.0	0	0.0	0	0.0	66.8
V-1917 Tie In to KO Drum	S-1035	N-1040	N-1030	20"	20	19.250	0.012	508	3	67.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	575.4
V-1912 to V-1917 Tie In	S-1045	N-1050	N-1040	20"	20	19.250	0.012	25	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	25.0
Sulfatreat to V-1912 Tie In	S-1055	N-1060	N-1050	20"	20	19.250	0.012	65	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	65.0
Sulfatreat Subheader #1	S-3995	N-4000	N-1060	4"	40	4.026	0.017	33	1	4.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	37.7
PSV-1811 to Subheader	S-4005	N-4010	N-4000	2"	80	1.939	0.019	6.5	3	6.8	0	0.0	0	0.0	1	3.2	1	9.7	0	0.0	26.2
Sulfatreat Subheader #2	S-4015	N-4020	N-4000	4"	40	4.026	0.017	10	0	0.0	0	0.0	0	0.0	1	6.7	0	0.0	0	0.0	16.7
PSV-1812 to Subheader	S-4025	N-4030	N-4020	2"	80	1.939	0.019	6.5	3	6.8	0	0.0	0	0.0	1	3.2	1	9.7	0	0.0	26.2
Sulfatreat Subheader #3	S-4035	N-4040	N-4020	4"	40	4.026	0.017	10	0	0.0	0	0.0	0	0.0	1	6.7	0	0.0	0	0.0	16.7
PSV-1813 to Subheader	S-4045	N-4050	N-4040	2"	80	1.939	0.019	6.5	3	6.8	0	0.0	0	0.0	1	3.2	1	9.7	0	0.0	26.2
Sulfatreat Subheader #4	S-4055	N-4060	N-4040	4"	40	4.026	0.017	10	0	0.0	0	0.0	0	0.0	1	6.7	0	0.0	0	0.0	16.7
PSV-1814 to Subheader	S-4065	N-4070	N-4060	2"	80	1.939	0.019	6.5	3	6.8	0	0.0	0	0.0	1	3.2	1	9.7	0	0.0	26.2

Targa Resources LLC
Valley Wells Compressor Station
External Fire Zone #2 - Sulfatreat Area
Flare Knockout Drum Evaluation

Inputs		
Density (Liquid)	40.00	lb/ft ³
Total Liquid In Flow	0	BPD
Low Liquid Level	7%	
Normal Liquid Level	14%	
High Liquid Level	30%	
Minimum Droplet Size	317	microns
Vessel Inner Diameter	6	ft
Selected Vessel Length	20	ft
Results from Hydraulic Evaluation		
Vapor Flowrate	31.63	MMSCFD
Operating Temperature	151.70	F
Operating Pressure	2.35	psig
Atmospheric Pressure	14.7	psia
MW (Vapor)	21.76	
Viscosity (Vapor)	0.01	cp
Density (Vapor)	0.057	lb/ft ³
Mass Flowrate	21.0	lb/s
Volumetric Flowrate	368.7	ft ³ /sec
Calculate Terminal Settling Velocity		
Minimum Droplet Size	0.001039	ft
c'(Re)^2	2428.7	
Drag Coefficient C'	1.67	
Terminal Settling Velocity	4.33	ft/s
Calculate Vessel Nozzle Separation Based on Low Level		
Full Area	28.3	ft ²
Required Fall Distance	5.6	ft
Required Residence Time	1.3	sec
Gas Velocity	13.04	ft/sec
Min. Nozzle Separation	16.8	ft
Calculate Vessel Nozzle Separation Based on Normal Level		
Level	0.8	ft
Required Fall Distance	5.2	ft
Required Residence Time	1.2	sec
α	43.9	degrees
x	2.1	ft
Circular Area	21.4	ft ²
Triangle Area	4.5	ft ²
Cross-Sectional Area	25.9	ft ²
Gas Velocity	14.25	ft/sec
Min. Nozzle Separation	17.0	ft
Calculate Vessel Nozzle Separation Based on High Level		
Level	1.8	ft
Required Fall Distance	4.2	ft
Required Residence Time	1.0	sec
α	66.4	degrees
x	2.7	ft
Circular Area	17.8	ft ²
Triangle Area	3.3	ft ²
Cross-Sectional Area	21.1	ft ²
Gas Velocity	17.44	ft/sec
Min. Nozzle Separation	16.9	ft

Targa Resources LLC
Valley Wells Compressor Station
External Fire Zone #2 - Sulfatreat Area
Flare Tip Radiation and Exit Velocity


Inputs

Atmospheric Pressure	P_{atm}	14.7	psia
Mass Flowrate	q_m	75,560	lb/hr
Temperature	T_j	152	F
Molecular Weight	M_j	21.76	lb/lbmole
Compressibility	Z_j	0.99	
Heat of Combustion	LHV	20,746	Btu/lb
Flare Inner Diameter	d_j	1.17	ft
Flare Height	h	100	ft
Fraction Heat Radiated	F	0.16	
Wind Speed	u_j	20	mph
Ambient Temperature	T_∞	60	F
Horizontal Distance to Flame Center	x_c	19	ft
Vertical Distance to Flame Center	y_c	30	ft


Outputs

Exit Mach Number	Ma_2	0.34	
Isothermal Sonic Velocity	u_s	1182.3	ft/sec
Exit Velocity	u_j	400.9	ft/sec
Mixture LEL	C_L	4.83	vol %
Wind Speed	u_j	29.3	ft/sec
LEL Concentration Parameter	C_{L-}	0.495	
Jet and Wind Thrust	$d_j R$	68.6	
Heat Released	Q	1,568	MMBtu/hr
Flame Center Height	h'	130	ft

Radiation Level	Distance from Base d_b (ft)	Distance from Center d_c (ft)
200	307	316
300	242	258
400	201	223
500	171	200
600	147	182
700	127	169
800	109	158
900	92	149
1,000	74	141
1,100	54	135
1,200	N/A	129
1,300	N/A	124
1,400	N/A	119
1,500	N/A	115
1,600	N/A	112
1,700	N/A	108
1,800	N/A	105
1,900	N/A	102
2,000	N/A	100
2,100	N/A	97
2,200	N/A	95
2,300	N/A	93
2,400	N/A	91
2,500	N/A	89
2,600	N/A	88
2,700	N/A	86
2,800	N/A	84
2,900	N/A	83
3,000	N/A	82



Radiation Versus Distance from Base of Stack External Fire Zone #2 - Sulfatreat Area




Targa Resources LLC
 Valley Wells Compressor Station
 External Fire Zone #2 - Sulfatreat Area
 Flare Gas LEL Calculation

Component	LEL (Vol %)	Gross Heating Value (Btu/scf)	Net Heating Value (Btu/scf)	MW	Mole Fraction	LEL Contribution (%)	HHV Contribution (Btu/scf)	LHV Contribution (Btu/scf)
Hydrogen Sulfide	4.3	1,573.4	1,450.6	34.08	0.0000	0.00000	0.0	0.0
Nitrogen	100.0	-	-	28.01	0.0016	0.16000	0.0	0.0
Methane	5.0	1,010.0	909.4	16.04	0.7639	3.81950	771.5	694.7
Carbon Dioxide	100.0	-	-	44.01	0.0008	0.08000	0.0	0.0
Ethane	3.0	1,769.7	1,618.7	30.07	0.1310	0.39300	231.8	212.0
Propane	2.1	2,516.2	2,314.9	44.10	0.0570	0.11970	143.4	131.9
Butane	1.6	3,262.4	3,010.8	58.12	0.0187	0.02992	61.0	56.3
Isobutane	1.6	3,252.0	3,000.4	58.12	0.0082	0.01312	26.7	24.6
Pentane	1.4	4,008.7	3,706.9	72.15	0.0051	0.00714	20.4	18.9
Isopentane	1.3	4,000.9	3,699.0	72.15	0.0046	0.00598	18.4	17.0
Hexane	1.1	4,756.0	4,403.8	86.18	0.0030	0.00330	14.3	13.2
Cyclohexane	1.3	4,443.5	4,144.6	84.16	0.0011	0.00143	4.9	4.6
Heptane	1.1	5,502.5	5,100.0	100.20	0.0004	0.00044	2.2	2.0
Octane	1.0	6,248.9	5,796.0	114.23	0.0019	0.00190	11.9	11.0
Benzene	1.2	3,741.9	3,590.9	78.11	0.0008	0.00096	3.0	2.9
Water	100.0	-	-	18.02	0.0019	0.19000	0.0	0.0
					1.0000	4.82639	1,310	1,189

- Mixture MW 21.75 lb/lbmole
- Mixture LEL 4.83 Vol %
- Mixture HHV 1,310 Btu/scf
- Mixture HHV 22,845 Btu/lbm
- Mixture LHV 1,189 Btu/scf
- Mixture LHV 20,746 Btu/lbm

API Standard 521 / ISO 23251



Key

X \bar{C}_L , the lower-explosive-limit concentration parameter for the flare gas, see Equation (C.7)

Y y_c , vertical distance from the stack to flame centre, expressed in feet

^a $(d_f R)$ is the parameter for jet thrust and wind thrust, see Equation (C.8).

Figure C.5 — Flame centre for flares and ignited vents — Vertical distance, y_c (USC units)

C.3.4 Calculation of the distance from the flame centre to the object or point being considered

The design basis for this calculation is as follows: The fraction of heat radiated, F , is 0,3. The heat liberated (see C.2.3), Q , is $6,3 \times 10^6$ kW ($2,15 \times 10^{10}$ Btu/h). Say the flare stack design must limit the maximum allowable radiation (see 6.4.2.3), K , is $9,5$ kW/m² (3 000 Btu/h.ft²).

In Equation (24), the value of τ should be assumed to be 1,0 (see C.3.6.3 and C.3.6.4). The distance from the flame centre to the object or point being considered (that is, the distance to the limit of the radiant heat intensity, such as grade level, an equipment platform, or a plant boundary), D , is then calculated as follows:


$$D = \sqrt{\frac{\tau \cdot F \cdot Q}{4\pi \cdot K}} \tag{24}$$

In SI units:

$$D = \sqrt{\frac{1,0 \times 0,3 \times 6,3 \times 10^6}{4\pi \times 9,5}} = 126 \text{ m}$$

Targa Resources LLC
 Valley Wells Compressor Station
 External Fire Zone #2 - Sulfatreat Area
 Horizontal Distance to Flame Center - API STD 521 Figure C-5

API Standard 521 / ISO 23251



Key

X C_L , the lower-explosive-limit concentration parameter for the flare gas, see Equation (C.7)

Y x_c , horizontal distance from the stack to flame centre, expressed in feet

^a $(d_j R)$ is the parameter for jet thrust and wind thrust, see Equation (C.8).

Figure C.3 — Flame centre for flares and ignited vents — Horizontal distance, x_c (USC units)

External Fire Supercritical Fluid Expansion



Equipment Data:

Equipment Tag:	V-1811	Type:	Pressure Vessel
Drawing:	D-2415-F-14	MAWP:	1440 psig
Description:	Sulfatreat Vessel	MAWT:	130 F

Scenario Description:

The Sulfatreat Vessel should always be free of liquid and the vapor would be supercritical at the relief pressure of 1742.4 psig. As such, an external fire could result in overpressure due to expansion of the fluid. The required relief rate was based on the normal sweet gas composition.. Initial operating conditions were 1,300 psig and 120 F. The heat input was based on the entire surface area of the vessel.

Scenario Calculation Results:

Required Rate:	18,890.1	lb/hr	Device Choke Pressure:	958.3	psig
Actual Capacity:	35,473.6	lb/hr	Outlet Temperature:	151.6	F
Required Area:	0.19	in ²	Outlet Mass Quality:	1.000	
Actual Area:	0.3568	in ²	Outlet Density:	0.048	lb/ft ³
Relief Pressure:	1742.4	psig	Outlet Ideal Cp/Cv:	1.215	
Relief Temperature:	234.5	F	Outlet Viscosity:	0.012	cP
Relief MW:	21.75		Inlet Non-Recoverble dP:	8.5	psi
Relief Mass Quality:	1.000		Inlet dP % Set:	0.6	% Set
Relief Density:	5.964	lb/ft ³	Built-Up Back Pressure:	243.5	psig
Relief SG:	0.750		Built-Up Back P % Set:	16.9	% Set
Relief Z:	0.860		Total Back Pressure:	243.5	psig
Relief Ideal Cp/Cv:	1.198		Total Back P % Set:	16.9	% Set
Relief Viscosity:	0.013				

External Fire Supercritical Fluid Expansion



Equipment Data:

Equipment Tag:	V-1811	Type:	Pressure Vessel
Drawing:	D-2415-F-14	MAWP:	1440 psig
Description:	Sulfatreat Vessel	MAWT:	130 F

Scenario Input Data:

Heat Input Calculation:

Length:	20 ft	Bottom Elevation:	3.5 ft
Diameter:	6 ft	Adequate Drainage:	<input type="checkbox"/>
Orientation:	Vertical	Insulation Factor:	1
Head Type:	2:1 Ellipsoidal	Include Entire Area:	<input checked="" type="checkbox"/>
Additional Wetted Area:	0 ft ²	Scenario Output Data:	
Level:	0%	Wetted Area:	455 ft ²
Level Basis:	Dry	Heat Input:	5.217 MMBtu/hr

Initial Mass and Expansion Rate Calculation:

Operating Pressure:	1300 psig	Vapor Mass:	3632.3 lb
Operating Pressure Basis:	Maximum Operating	Initial Density:	6.12 lb/ft ³
Bubblepoint Liquid:	<input type="checkbox"/>	Initial Specific Volume:	0.1634 ft ³ /lb
Operating Temperature:	120 F	Initial Relief Temperature:	224.5 F
Set Pressure:	1440 psig	Start Temp. for Expansion:	224.5 F
Allowable Overpressure:	21.0%	Average Mass:	3756.6 lb
Constant Back Pressure:	0 psig	Start Density for Expansion:	6.115 lb/ft ³
Temperature Increment:	10 F	Start Cp for Expansion:	0.692 Btu/lb/F
Use Thermodynamics:	<input checked="" type="checkbox"/>	Relief Cp:	0.689 Btu/lb/F
Relief Device KdV:	0.855	Average Cp:	0.69 Btu/lb/F
Relief Device KdL:	0.670	Start Enthalpy for Expansion:	5349.9 Btu/lb
Nozzle Sizing:	API Numerical Integration Vapor	Stop Enthalpy for Expansion:	5500.2 Btu/lb/F
Outlet Pipe Sizing:	Isothermal	Maximum Volumetric Flow:	143.7 ft ³ /hr
Operating Vapor Density:	6.118 lb/ft ³	Heat Increment:	25939.1 Btu
Operating Liquid Density:	6.118 lb/ft ³	Time Increment:	0.30 min
Total Volume:	622 ft ³	Relief Mass Flux:	3976.9 lb/sec/ft ²
Initial Mass:	3805.6 lb	Kd:	0.855
Liquid Mass:	173.3 lb		

Notes:

External Fire Supercritical Fluid Expansion



Equipment Data:

Equipment Tag:	V-1811	Type:	Pressure Vessel
Drawing:	D-2415-F-14	MAWP:	1440 psig
Description:	Sulfatreat Vessel	MAWT:	130 F

Relief Stream Composition:

Component	V-1811 Fire Vapor Relief	Valley Wells Sweet HP Gas	Valley Wells Sweet HP Gas
	Mole Fraction	Mole Fraction	Mole Fraction
hydrogen sulfide	0.0000	0.0000	0.0000
nitrogen	0.0016	0.0016	0.0016
methane	0.7639	0.7639	0.7639
carbon dioxide	0.0008	0.0008	0.0008
ethane	0.1310	0.1310	0.1310
propane	0.0570	0.0570	0.0570
butane	0.0187	0.0187	0.0187
isobutane	0.0082	0.0082	0.0082
ipentane	0.0051	0.0051	0.0051
isopentane	0.0046	0.0046	0.0046
hexane	0.0030	0.0030	0.0030
cyclohexane	0.0011	0.0011	0.0011
heptane	0.0004	0.0004	0.0004
octane	0.0019	0.0019	0.0019
benzene	0.0008	0.0008	0.0008
ethylbenzene	0.0000	0.0000	0.0000
water	0.0019	0.0019	0.0019

External Fire Supercritical Fluid Expansion



Equipment Data:

Equipment Tag:	V-1812	Type:	Pressure Vessel
Drawing:	D-2415-F-14	MAWP:	1440 psig
Description:	SulfaTreat Vessel	MAWT:	130 F

Scenario Description:

The Sulfatreat Vessel should always be free of liquid and the vapor would be supercritical at the relief pressure of 1742.4 psig. As such, an external fire could result in overpressure due to expansion of the fluid. The required relief rate was based on the normal sweet gas composition.. Initial operating conditions were 1,300 psig and 120 F. The heat input was based on the entire surface area of the vessel.

Scenario Calculation Results:

Required Rate:	18,890.1	lb/hr	Device Choke Pressure:	958.3	psig
Actual Capacity:	35,473.6	lb/hr	Outlet Temperature:	151.6	F
Required Area:	0.19	in ²	Outlet Mass Quality:	1.000	
Actual Area:	0.3568	in ²	Outlet Density:	0.048	lb/ft ³
Relief Pressure:	1742.4	psig	Outlet Ideal Cp/Cv:	1.215	
Relief Temperature:	234.5	F	Outlet Viscosity:	0.012	cP
Relief MW:	21.75		Inlet Non-Recoverble dP:	8.5	psi
Relief Mass Quality:	1.000		Inlet dP % Set:	0.6	% Set
Relief Density:	5.964	lb/ft ³	Built-Up Back Pressure:	243.5	psig
Relief SG:	0.750		Built-Up Back P % Set:	16.9	% Set
Relief Z:	0.860		Total Back Pressure:	243.5	psig
Relief Ideal Cp/Cv:	1.198		Total Back P % Set:	16.9	% Set
Relief Viscosity:	0.013				

External Fire Supercritical Fluid Expansion



Equipment Data:

Equipment Tag:	V-1812	Type:	Pressure Vessel
Drawing:	D-2415-F-14	MAWP:	1440 psig
Description:	SulfaTreat Vessel	MAWT:	130 F

Scenario Input Data:

Heat Input Calculation:

Length:	20 ft	Bottom Elevation:	3.5 ft
Diameter:	6 ft	Adequate Drainage:	<input type="checkbox"/>
Orientation:	Vertical	Insulation Factor:	1
Head Type:	2:1 Ellipsoidal	Include Entire Area:	<input checked="" type="checkbox"/>
Additional Wetted Area:	0 ft ²	Scenario Output Data:	
Level:	0%	Wetted Area:	455 ft ²
Level Basis:	Dry	Heat Input:	5.217 MMBtu/hr

Initial Mass and Expansion Rate Calculation:

Operating Pressure:	1300 psig	Vapor Mass:	3632.3 lb
Operating Pressure Basis:	Maximum Operating	Initial Density:	6.12 lb/ft ³
Bubblepoint Liquid:	<input type="checkbox"/>	Initial Specific Volume:	0.1634 ft ³ /lb
Operating Temperature:	120 F	Initial Relief Temperature:	224.5 F
Set Pressure:	1440 psig	Start Temp. for Expansion:	224.5 F
Allowable Overpressure:	21.0%	Average Mass:	3756.6 lb
Constant Back Pressure:	0 psig	Start Density for Expansion:	6.115 lb/ft ³
Temperature Increment:	10 F	Start Cp for Expansion:	0.692 Btu/lb/F
Use Thermodynamics:	<input checked="" type="checkbox"/>	Relief Cp:	0.689 Btu/lb/F
Relief Device KdV:	0.855	Average Cp:	0.69 Btu/lb/F
Relief Device KdL:	0.670	Start Enthalpy for Expansion:	5349.9 Btu/lb
Nozzle Sizing:	API Numerical Integration Vapor	Stop Enthalpy for Expansion:	5500.2 Btu/lb/F
Outlet Pipe Sizing:	Isothermal	Maximum Volumetric Flow:	143.7 ft ³ /hr
Operating Vapor Density:	6.118 lb/ft ³	Heat Increment:	25939.1 Btu
Operating Liquid Density:	6.118 lb/ft ³	Time Increment:	0.30 min
Total Volume:	622 ft ³	Relief Mass Flux:	3976.9 lb/sec/ft ²
Initial Mass:	3805.6 lb	Kd:	0.855
Liquid Mass:	173.3 lb		

Notes:

External Fire Supercritical Fluid Expansion



Equipment Data:

Equipment Tag:	V-1812	Type:	Pressure Vessel
Drawing:	D-2415-F-14	MAWP:	1440 psig
Description:	SulfaTreat Vessel	MAWT:	130 F

Relief Stream Composition:

Component	V-1811_2_3_4 Fire Vapor Relief	Valley Wells Sweet HP Gas	Valley Wells Sweet HP Gas
	Mole Fraction	Mole Fraction	Mole Fraction
hydrogen sulfide	0.0000	0.0000	0.0000
nitrogen	0.0016	0.0016	0.0016
methane	0.7639	0.7639	0.7639
carbon dioxide	0.0008	0.0008	0.0008
ethane	0.1310	0.1310	0.1310
propane	0.0570	0.0570	0.0570
butane	0.0187	0.0187	0.0187
isobutane	0.0082	0.0082	0.0082
ipentane	0.0051	0.0051	0.0051
isopentane	0.0046	0.0046	0.0046
hexane	0.0030	0.0030	0.0030
cyclohexane	0.0011	0.0011	0.0011
heptane	0.0004	0.0004	0.0004
octane	0.0019	0.0019	0.0019
benzene	0.0008	0.0008	0.0008
ethylbenzene	0.0000	0.0000	0.0000
water	0.0019	0.0019	0.0019

External Fire Supercritical Fluid Expansion



Equipment Data:

Equipment Tag:	V-1813	Type:	Pressure Vessel
Drawing:	D-2415-F-14	MAWP:	1440 psig
Description:	SulfaTreat Vessel	MAWT:	130 F

Scenario Description:

The Sulfatreat Vessel should always be free of liquid and the vapor would be supercritical at the relief pressure of 1742.4 psig. As such, an external fire could result in overpressure due to expansion of the fluid. The required relief rate was based on the normal sweet gas composition.. Initial operating conditions were 1,300 psig and 120 F. The heat input was based on the entire surface area of the vessel.

Scenario Calculation Results:

Required Rate:	18,890.1	lb/hr	Device Choke Pressure:	958.3	psig
Actual Capacity:	35,473.6	lb/hr	Outlet Temperature:	151.6	F
Required Area:	0.19	in ²	Outlet Mass Quality:	1.000	
Actual Area:	0.3568	in ²	Outlet Density:	0.048	lb/ft ³
Relief Pressure:	1742.4	psig	Outlet Ideal Cp/Cv:	1.215	
Relief Temperature:	234.5	F	Outlet Viscosity:	0.012	cP
Relief MW:	21.75		Inlet Non-Recoverble dP:	8.5	psi
Relief Mass Quality:	1.000		Inlet dP % Set:	0.6	% Set
Relief Density:	5.964	lb/ft ³	Built-Up Back Pressure:	243.5	psig
Relief SG:	0.750		Built-Up Back P % Set:	16.9	% Set
Relief Z:	0.860		Total Back Pressure:	243.5	psig
Relief Ideal Cp/Cv:	1.198		Total Back P % Set:	16.9	% Set
Relief Viscosity:	0.013				

External Fire Supercritical Fluid Expansion



Equipment Data:

Equipment Tag:	V-1813	Type:	Pressure Vessel
Drawing:	D-2415-F-14	MAWP:	1440 psig
Description:	SulfaTreat Vessel	MAWT:	130 F

Scenario Input Data:

Heat Input Calculation:

Length:	20 ft	Bottom Elevation:	3.5 ft
Diameter:	6 ft	Adequate Drainage:	<input type="checkbox"/>
Orientation:	Vertical	Insulation Factor:	1
Head Type:	2:1 Ellipsoidal	Include Entire Area:	<input checked="" type="checkbox"/>
Additional Wetted Area:	0 ft ²	Scenario Output Data:	
Level:	0%	Wetted Area:	455 ft ²
Level Basis:	Dry	Heat Input:	5.217 MMBtu/hr

Initial Mass and Expansion Rate Calculation:

Operating Pressure:	1300 psig	Vapor Mass:	3632.3 lb
Operating Pressure Basis:	Maximum Operating	Initial Density:	6.12 lb/ft ³
Bubblepoint Liquid:	<input type="checkbox"/>	Initial Specific Volume:	0.1634 ft ³ /lb
Operating Temperature:	120 F	Initial Relief Temperature:	224.5 F
Set Pressure:	1440 psig	Start Temp. for Expansion:	224.5 F
Allowable Overpressure:	21.0%	Average Mass:	3756.6 lb
Constant Back Pressure:	0 psig	Start Density for Expansion:	6.115 lb/ft ³
Temperature Increment:	10 F	Start Cp for Expansion:	0.692 Btu/lb/F
Use Thermodynamics:	<input checked="" type="checkbox"/>	Relief Cp:	0.689 Btu/lb/F
Relief Device KdV:	0.855	Average Cp:	0.69 Btu/lb/F
Relief Device KdL:	0.670	Start Enthalpy for Expansion:	5349.9 Btu/lb
Nozzle Sizing:	API Numerical Integration Vapor	Stop Enthalpy for Expansion:	5500.2 Btu/lb/F
Outlet Pipe Sizing:	Isothermal	Maximum Volumetric Flow:	143.7 ft ³ /hr
Operating Vapor Density:	6.118 lb/ft ³	Heat Increment:	25939.1 Btu
Operating Liquid Density:	6.118 lb/ft ³	Time Increment:	0.30 min
Total Volume:	622 ft ³	Relief Mass Flux:	3976.9 lb/sec/ft ²
Initial Mass:	3805.6 lb	Kd:	0.855
Liquid Mass:	173.3 lb		

Notes:



Equipment Data:

Equipment Tag:	V-1813	Type:	Pressure Vessel
Drawing:	D-2415-F-14	MAWP:	1440 psig
Description:	SulfaTreat Vessel	MAWT:	130 F

Relief Stream Composition:

Component	V-1811_2_3_4 Fire Vapor Relief	Valley Wells Sweet HP Gas	Valley Wells Sweet HP Gas
	Mole Fraction	Mole Fraction	Mole Fraction
hydrogen sulfide	0.0000	0.0000	0.0000
nitrogen	0.0016	0.0016	0.0016
methane	0.7639	0.7639	0.7639
carbon dioxide	0.0008	0.0008	0.0008
ethane	0.1310	0.1310	0.1310
propane	0.0570	0.0570	0.0570
butane	0.0187	0.0187	0.0187
isobutane	0.0082	0.0082	0.0082
ipentane	0.0051	0.0051	0.0051
isopentane	0.0046	0.0046	0.0046
hexane	0.0030	0.0030	0.0030
cyclohexane	0.0011	0.0011	0.0011
heptane	0.0004	0.0004	0.0004
octane	0.0019	0.0019	0.0019
benzene	0.0008	0.0008	0.0008
ethylbenzene	0.0000	0.0000	0.0000
water	0.0019	0.0019	0.0019

External Fire Supercritical Fluid Expansion



Equipment Data:

Equipment Tag:	V-1814	Type:	Pressure Vessel
Drawing:	D-2415-F-14	MAWP:	1440 psig
Description:	SulfaTreat Vessel	MAWT:	130 F

Scenario Description:

The Sulfatreat Vessel should always be free of liquid and the vapor would be supercritical at the relief pressure of 1742.4 psig. As such, an external fire could result in overpressure due to expansion of the fluid. The required relief rate was based on the normal sweet gas composition.. Initial operating conditions were 1,300 psig and 120 F. The heat input was based on the entire surface area of the vessel.

Scenario Calculation Results:

Required Rate:	18,890.1	lb/hr	Device Choke Pressure:	958.3	psig
Actual Capacity:	35,473.6	lb/hr	Outlet Temperature:	151.6	F
Required Area:	0.19	in ²	Outlet Mass Quality:	1.000	
Actual Area:	0.3568	in ²	Outlet Density:	0.048	lb/ft ³
Relief Pressure:	1742.4	psig	Outlet Ideal Cp/Cv:	1.215	
Relief Temperature:	234.5	F	Outlet Viscosity:	0.012	cP
Relief MW:	21.75		Inlet Non-Recoverble dP:	8.5	psi
Relief Mass Quality:	1.000		Inlet dP % Set:	0.6	% Set
Relief Density:	5.964	lb/ft ³	Built-Up Back Pressure:	243.5	psig
Relief SG:	0.750		Built-Up Back P % Set:	16.9	% Set
Relief Z:	0.860		Total Back Pressure:	243.5	psig
Relief Ideal Cp/Cv:	1.198		Total Back P % Set:	16.9	% Set
Relief Viscosity:	0.013				

External Fire Supercritical Fluid Expansion



Equipment Data:

Equipment Tag:	V-1814	Type:	Pressure Vessel
Drawing:	D-2415-F-14	MAWP:	1440 psig
Description:	SulfaTreat Vessel	MAWT:	130 F

Scenario Input Data:

Heat Input Calculation:

Length:	20 ft	Bottom Elevation:	3.5 ft
Diameter:	6 ft	Adequate Drainage:	<input type="checkbox"/>
Orientation:	Vertical	Insulation Factor:	1
Head Type:	2:1 Ellipsoidal	Include Entire Area:	<input checked="" type="checkbox"/>
Additional Wetted Area:	0 ft ²	Scenario Output Data:	
Level:	0%	Wetted Area:	455 ft ²
Level Basis:	Dry	Heat Input:	5.217 MMBtu/hr

Initial Mass and Expansion Rate Calculation:

Operating Pressure:	1300 psig	Vapor Mass:	3632.3 lb
Operating Pressure Basis:	Maximum Operating	Initial Density:	6.12 lb/ft ³
Bubblepoint Liquid:	<input type="checkbox"/>	Initial Specific Volume:	0.1634 ft ³ /lb
Operating Temperature:	120 F	Initial Relief Temperature:	224.5 F
Set Pressure:	1440 psig	Start Temp. for Expansion:	224.5 F
Allowable Overpressure:	21.0%	Average Mass:	3756.6 lb
Constant Back Pressure:	0 psig	Start Density for Expansion:	6.115 lb/ft ³
Temperature Increment:	10 F	Start Cp for Expansion:	0.692 Btu/lb/F
Use Thermodynamics:	<input checked="" type="checkbox"/>	Relief Cp:	0.689 Btu/lb/F
Relief Device KdV:	0.855	Average Cp:	0.69 Btu/lb/F
Relief Device KdL:	0.670	Start Enthalpy for Expansion:	5349.9 Btu/lb
Nozzle Sizing:	API Numerical Integration Vapor	Stop Enthalpy for Expansion:	5500.2 Btu/lb/F
Outlet Pipe Sizing:	Isothermal	Maximum Volumetric Flow:	143.7 ft ³ /hr
Operating Vapor Density:	6.118 lb/ft ³	Heat Increment:	25939.1 Btu
Operating Liquid Density:	6.118 lb/ft ³	Time Increment:	0.30 min
Total Volume:	622 ft ³	Relief Mass Flux:	3976.9 lb/sec/ft ²
Initial Mass:	3805.6 lb	Kd:	0.855
Liquid Mass:	173.3 lb		

Notes:

External Fire Supercritical Fluid Expansion



Equipment Data:

Equipment Tag:	V-1814	Type:	Pressure Vessel
Drawing:	D-2415-F-14	MAWP:	1440 psig
Description:	SulfaTreat Vessel	MAWT:	130 F

Relief Stream Composition:

Component	V-1811_2_3_4 Fire Vapor Relief	Valley Wells Sweet HP Gas	Valley Wells Sweet HP Gas
	Mole Fraction	Mole Fraction	Mole Fraction
hydrogen sulfide	0.0000	0.0000	0.0000
nitrogen	0.0016	0.0016	0.0016
methane	0.7639	0.7639	0.7639
carbon dioxide	0.0008	0.0008	0.0008
ethane	0.1310	0.1310	0.1310
propane	0.0570	0.0570	0.0570
butane	0.0187	0.0187	0.0187
isobutane	0.0082	0.0082	0.0082
ipentane	0.0051	0.0051	0.0051
isopentane	0.0046	0.0046	0.0046
hexane	0.0030	0.0030	0.0030
cyclohexane	0.0011	0.0011	0.0011
heptane	0.0004	0.0004	0.0004
octane	0.0019	0.0019	0.0019
benzene	0.0008	0.0008	0.0008
ethylbenzene	0.0000	0.0000	0.0000
water	0.0019	0.0019	0.0019

APPENDIX F – Fire Zone #3 – Closed Drain Tank Area Details

Hydraulic Detailed Results

Knockout Drum Detailed Results

Flare Detailed Sizing Results

Relief Load Calculations



Targa Resources LLC
Valley Wells Compressor Station
External Fire Zone #3 - Closed Drain Tank Area

Client:	Targa Resources LLC		Increments/Seg.	5
Project:	Valley Wells Compressor Station		P Atm	14.7 psia
Project Number:	23-1005		Exit Pressure	2 psig
Date:	Mar-24		Roughness	0.00015 feet
Created by:	Rob Kreder		Friction dP Only	FALSE

Input Data						Calculated Values						Inlet Conditions				Exit Conditions				Results				
Description	Segment	Start Node	End Node	Pipe NPS	Pipe Sch	Pipe ID (inches)	Equivalent Length (ft)	Segment Flow (lb/hr)	Segment Flow (MMSCFD)	Moody f	Fluid MW	P ₁ (psig)	T ₁ (F)	K ₁	ρ ₁ (lb/ft ³)	P ₂ (psig)	T ₂ (F)	K ₂	Z ₂	Segment ΔP (psi)	Max. Velocity (ft/sec)	Sonic Velocity (ft/sec)	Segment Max. Mach Number	Choke P at Segment Exit (psig)
Reducer To Flare Base	S-1005	N-1010	N-1000	12"	STD	12.000	2.0	213,432	26.59	0.013	73.12	2.2	351.8	1.052	0.145	2.0	351.8	1.052	0.142	0.2	531.6	762.1	0.70	-3.1
KO Drum to Reducer	S-1015	N-1020	N-1010	20"	20	19.250	86.4	213,432	26.59	0.012	73.12	2.7	351.9	1.052	0.149	2.2	351.8	1.052	0.145	0.5	202.3	762.1	0.27	-10.2
KO Drum	S-1025	N-1030	N-1020	20"	20	19.250	66.8	213,432	26.59	0.012	73.12	3.1	351.9	1.052	0.152	2.7	351.9	1.052	0.149	0.3	196.9	762.2	0.26	-10.2
V-1917 Tie In to KO Drum	S-1035	N-1040	N-1030	20"	20	19.250	575.4	213,432	26.59	0.012	73.12	5.7	352.2	1.052	0.175	3.1	351.9	1.052	0.152	2.7	193.0	762.2	0.25	-10.2
PSV-1917 to Main Header	S-2995	N-3000	N-1040	3"	40	3.068	43.7	82,727	10.17	0.017	74.07	147.0	374.9	1.050	1.573	53.8	363.9	1.051	0.613	93.2	760.0	760.0	1.00	53.8
V-1912 to V-1917 Tie In	S-1045	N-1050	N-1040	20"	20	19.250	25.0	130,705	16.42	0.012	72.52	5.8	348.0	1.053	0.175	5.7	348.0	1.053	0.174	0.0	103.2	763.8	0.14	-11.9
PSV-1912 to Main Header	S-3005	N-3010	N-1050	4"	40	4.026	56.4	130,705	16.42	0.016	72.52	131.6	362.7	1.052	1.389	48.4	352.8	1.053	0.556	83.3	763.8	763.8	1.00	48.4



Targa Resources LLC
Valley Wells Compressor Station
External Fire Zone #3 - Closed Drain Tank Area

Client:	Targa Resources LLC
Project:	Valley Wells Compressor Station
Project Number:	23-1005
Date:	Mar-24
Created by:	Rob Kreder

Segment Data

Description	Segment	Start Node	End Node	Pipe NPS	Pipe Sch	Pipe ID (inches)	Moody F	Pipe Length (ft)	# 90 Elbows	Eq. Length 90 Elbows	# 45 Elbows	Eq. Length 45 Elbows	Entrances	Eq. Length Entrances	Tee Through	Eq. Length Tee Through	Tee Branch	Eq. Length Tee Branch	Ball Valve	Eq. Length Ball Valve	Equivalent Length (ft)
Reducer To Flare Base	S-1005	N-1010	N-1000	12"	STD	12.000	0.013	2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	2.0
KO Drum to Reducer	S-1015	N-1020	N-1010	20"	20	19.250	0.012	19	3	67.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	86.4
KO Drum	S-1025	N-1030	N-1020	20"	20	19.250	0.012	0	0	0.0	0	0.0	1	66.8	0	0.0	0	0.0	0	0.0	66.8
V-1917 Tie In to KO Drum	S-1035	N-1040	N-1030	20"	20	19.250	0.012	508	3	67.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	575.4
PSV-1917 to Main Header	S-2995	N-3000	N-1040	3"	40	3.068	0.018	35	1	3.6	0	0.0	0	0.0	1	5.1	0	0.0	0	0.0	43.7
V-1912 to V-1917 Tie In	S-1045	N-1050	N-1040	20"	20	19.250	0.012	25	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0	25.0
PSV-1912 to Main Header	S-3005	N-3010	N-1050	4"	40	4.026	0.017	45	1	4.7	0	0.0	0	0.0	1	6.7	0	0.0	0	0.0	56.4

Targa Resources LLC
Valley Wells Compressor Station
External Fire Zone #3 - Closed Drain Tank Area
Flare Knockout Drum Evaluation

Inputs		
Density (Liquid)	40.00	lb/ft ³
Total Liquid In Flow	0	BPD
Low Liquid Level	7%	
Normal Liquid Level	14%	
High Liquid Level	30%	
Minimum Droplet Size	463	microns
Vessel Inner Diameter	6	ft
Selected Vessel Length	20	ft
Results from Hydraulic Evaluation		
Vapor Flowrate	26.59	MMSCFD
Operating Temperature	351.90	F
Operating Pressure	3.06	psig
Atmospheric Pressure	14.7	psia
MW (Vapor)	73.12	
Viscosity (Vapor)	0.01	cp
Density (Vapor)	0.152	lb/ft ³
Mass Flowrate	59.4	lb/s
Volumetric Flowrate	390.6	ft ³ /sec
Calculate Terminal Settling Velocity		
Minimum Droplet Size	0.001519	ft
c'(Re)^2	20174.5	
Drag Coefficient C'	0.81	
Terminal Settling Velocity	4.58	ft/s
Calculate Vessel Nozzle Separation Based on Low Level		
Full Area	28.3	ft ²
Required Fall Distance	5.6	ft
Required Residence Time	1.2	sec
Gas Velocity	13.81	ft/sec
Min. Nozzle Separation	16.8	ft
Calculate Vessel Nozzle Separation Based on Normal Level		
Level	0.8	ft
Required Fall Distance	5.2	ft
Required Residence Time	1.1	sec
α	43.9	degrees
x	2.1	ft
Circular Area	21.4	ft ²
Triangle Area	4.5	ft ²
Cross-Sectional Area	25.9	ft ²
Gas Velocity	15.10	ft/sec
Min. Nozzle Separation	17.0	ft
Calculate Vessel Nozzle Separation Based on High Level		
Level	1.8	ft
Required Fall Distance	4.2	ft
Required Residence Time	0.9	sec
α	66.4	degrees
x	2.7	ft
Circular Area	17.8	ft ²
Triangle Area	3.3	ft ²
Cross-Sectional Area	21.1	ft ²
Gas Velocity	18.47	ft/sec
Min. Nozzle Separation	16.9	ft

Targa Resources LLC
Valley Wells Compressor Station
External Fire Zone #3 - Closed Drain Tank Area
Flare Tip Radiation and Exit Velocity


Inputs

Atmospheric Pressure	P_{atm}	14.7	psia
Mass Flowrate	q_m	213,432	lb/hr
Temperature	T_j	352	F
Molecular Weight	M_j	73.12	lb/lbmole
Compressibility	Z_j	0.99	
Heat of Combustion	LHV	20,811	Btu/lb
Flare Inner Diameter	d_j	1.17	ft
Flare Height	h	100	ft
Fraction Heat Radiated	F	0.16	
Wind Speed	u_j	20	mph
Ambient Temperature	T_∞	60	F
Horizontal Distance to Flame Center	x_c	21	ft
Vertical Distance to Flame Center	y_c	45	ft


Outputs

Exit Mach Number	Ma_2	0.60	
Isothermal Sonic Velocity	u_s	743.0	ft/sec
Exit Velocity	u_j	447.2	ft/sec
Mixture LEL	C_L	1.56	vol %
Wind Speed	u_j	29.3	ft/sec
LEL Concentration Parameter	C_L	0.601	
Jet and Wind Thrust	d_jR	121.7	
Heat Released	Q	4,442	MMBtu/hr
Flame Center Height	h'	145	ft


Radiation Level	Distance from Base d_b (ft)	Distance from Center d_c (ft)
200	533	532
300	430	434
400	368	376
500	324	336
600	292	307
700	265	284
800	244	266
900	225	251
1,000	209	238
1,100	195	227
1,200	183	217
1,300	171	209
1,400	160	201
1,500	150	194
1,600	141	188
1,700	132	182
1,800	123	177
1,900	114	173
2,000	106	168
2,100	98	164
2,200	89	160
2,300	81	157
2,400	71	154
2,500	61	150
2,600	48	147
2,700	N/A	145
2,800	N/A	142
2,900	N/A	140
3,000	N/A	137



Radiation Versus Distance from Base of Stack External Fire Zone #3 - Closed Drain Tank Area



API Standard 521 / ISO 23251



Key

X C_L , the lower-explosive-limit concentration parameter for the flare gas, see Equation (C.7)

Y y_c , vertical distance from the stack to flame centre, expressed in feet

^a $(d_f R)$ is the parameter for jet thrust and wind thrust, see Equation (C.8).

Figure C.5 — Flame centre for flares and ignited vents — Vertical distance, y_c (USC units)

C.3.4 Calculation of the distance from the flame centre to the object or point being considered

The design basis for this calculation is as follows: The fraction of heat radiated, F , is 0,3. The heat liberated (see C.2.3), Q , is $6,3 \times 10^6$ kW ($2,15 \times 10^{10}$ Btu/h). Say the flare stack design must limit the maximum allowable radiation (see 6.4.2.3), K , is $9,5$ kW/m² (3 000 Btu/h.ft²).

In Equation (24), the value of τ should be assumed to be 1,0 (see C.3.6.3 and C.3.6.4). The distance from the flame centre to the object or point being considered (that is, the distance to the limit of the radiant heat intensity, such as grade level, an equipment platform, or a plant boundary), D , is then calculated as follows:


$$D = \sqrt{\frac{\tau \cdot F \cdot Q}{4\pi \cdot K}} \tag{24}$$

In SI units:

$$D = \sqrt{\frac{1,0 \times 0,3 \times 6,3 \times 10^6}{4\pi \times 9,5}} = 126 \text{ m}$$

Targa Resources LLC
 Valley Wells Compressor Station
 External Fire Zone #3 - Closed Drain Tank Area
 Horizontal Distance to Flame Center - API STD 521 Figure C-5

API Standard 521 / ISO 23251



Key

X C_L , the lower-explosive-limit concentration parameter for the flare gas, see Equation (C.7)

Y x_c , horizontal distance from the stack to flame centre, expressed in feet

^a $(d_j R)$ is the parameter for jet thrust and wind thrust, see Equation (C.8).

Figure C.3 — Flame centre for flares and ignited vents — Horizontal distance, x_c (USC units)



Equipment Data:

Equipment Tag:	V-1912	Type:	Pressure Vessel
Drawing:	D-2415-F-23	MAWP:	250 psig
Description:	Closed Drain Tank	MAWT:	150 F

Scenario Description:

The Closed Drain Tank contains primarily hydrocarbon with some water that could vaporize in the event of an external fire potentially resulting in overpressure. The required relief rate was based on hydrocarbon that is the worst case and the liquids composition from the Condensate Flash Tank was used as the basis at the relief pressure of 302.5 psig. The liquid level of 70% was based on the field estimated location of LSHH-1912.

Scenario Calculation Results:

Required Rate:	130705	lb/hr	Device Choke Pressure:	187.6	psig
Actual Capacity:	61950.8	lb/hr	Outlet Temperature:	347.3	F
Required Area:	6.420	in2	Outlet Mass Quality:	1.000	
Actual Area:	3.043	in2	Outlet Density:	0.122	lb/ft3
Relief Pressure:	302.5	psig	Outlet Ideal Cp/Cv:	1.053	
Relief Temperature:	385.5	F	Outlet Viscosity:	0.010	cP
Relief MW:	72.53		Inlet Non-Recoverble dP:	1.3	psi
Relief Mass Quality:	1.000		Inlet dP % Set:	0.5	% Set
Relief Density:	3.60	lb/ft3	Built-Up Back Pressure:	54.8	psig
Relief SG:	2.501		Built-Up Back P % Set:	21.9	% Set
Relief Z:	0.71		Total Back Pressure:	54.8	psig
Relief Ideal Cp/Cv:	1.05		Total Back P % Set:	21.9	% Set
Relief Viscosity:	0.011	cP			



Equipment Data:

Equipment Tag:	V-1912	Type:	Pressure Vessel
Drawing:	D-2415-F-23	MAWP:	250 psig
Description:	Closed Drain Tank	MAWT:	150 F

Scenario Input Data:

Length: ft

Diameter: in

Orientation:

Head Type:

Level Basis:

Additional Wetted Area: ft2

Level:

Bottom Elevation: ft

Area Exponent:

Adequate Drainage:

Insulation Factor:

Start Mass % Vapor:

Finish Mass % Vapor:

Remove Sensible Heat: Correct for Densities:

Set Pressure: psig

Allowable Overpressure:

Constant Back Pressure: psig

Use Thermodynamics:

Thermo Package:

Relief Device Kd:

Nozzle Sizing:

Outlet Pipe Sizing:

Scenario Output Data:

Wetted Area:	<input type="text" value="1049.8"/>	ft2
Fire Heat Input:	<input type="text" value="10.35"/>	MMBtu/hr
Total Heat/lb Vaporized:	<input type="text" value="260.0"/>	Btu/lb
Sensible Heat/lb Vaporized:	<input type="text" value="190.1"/>	Btu/lb
Latent Heat:	<input type="text" value="69.9"/>	Btu/lb
Initial Relief Temperature:	<input type="text" value="373.6"/>	F
Temp. at Start Quality:	<input type="text" value="373.6"/>	F
Cp at Start Quality:	<input type="text" value="0.795"/>	Btu/lb/F
Cp at Final Quality:	<input type="text" value="0.804"/>	Btu/lb/F
Liquid Density:	<input type="text" value="30.56"/>	lb/ft3
Required Mass Rate:	<input type="text" value="130705.0"/>	lb/hr
Required Std. Vol. Rate:	<input type="text" value="16.41"/>	MMSCFD
Required Air Rate:	<input type="text" value="1379117.3"/>	scfh air
Relief Mass Flux:	<input type="text" value="814.3"/>	lb/sec/ft2

Notes:



Equipment Data:

Equipment Tag:	V-1912	Type:	Pressure Vessel
Drawing:	D-2415-F-23	MAWP:	250 psig
Description:	Closed Drain Tank	MAWT:	150 F

Liquid Stream Description: Valley Wells Condensate Flash Tank Liquid

Relief Stream Description: V-1912 Fire HC Vapor

Component	Liquid Stream Mole Fraction	Relief Stream Mole Fraction
carbon dioxide	0.0001	0.0004
nitrogen	0.0000	0.0000
methane	0.0050	0.0268
ethane	0.0158	0.0573
propane	0.0478	0.1240
isobutane	0.0250	0.0492
butane	0.0935	0.1672
isopentane	0.0619	0.0829
pentane	0.0883	0.1107
hexane	0.0466	0.0406
benzene	0.0354	0.0299
cyclohexane	0.0611	0.0448
2-methylhexane	0.0722	0.0489
3-methylhexane	0.0757	0.0500
heptane	0.0331	0.0204
octane	0.3385	0.1470



Equipment Data:

Equipment Tag:	V-1917	Type:	Pressure Vessel
Drawing:	D-2415-F24A	MAWP:	275 psig
Description:	Condensate Flash Tank	MAWT:	300 F

Scenario Description:

Hydrocarbon liquid could be present and overpressure could occur due to vaporization of the liquid in the event of an external fire. The liquid composition from the Condensate Flash Drum from the MEB was used as the basis with the level at the estimated 70% location of LSHH-1917.

Scenario Calculation Results:

Required Rate:	82727.4	lb/hr	Device Choke Pressure:	206.3	psig
Actual Capacity:	28823.3	lb/hr	Outlet Temperature:	357.8	F
Required Area:	2.620	in ²	Outlet Mass Quality:	1.000	
Actual Area:	0.913	in ²	Outlet Density:	0.123	lb/ft ³
Relief Pressure:	332.8	psig	Outlet Ideal Cp/Cv:	1.051	
Relief Temperature:	400.1	F	Outlet Viscosity:	0.010	cP
Relief MW:	74.07		Inlet Non-Recoverble dP:	2.6	psi
Relief Mass Quality:	1.000		Inlet dP % Set:	1.0	% Set
Relief Density:	4.14	lb/ft ³	Built-Up Back Pressure:	44.5	psig
Relief SG:	2.554		Built-Up Back P % Set:	16.2	% Set
Relief Z:	0.67		Total Back Pressure:	44.5	psig
Relief Ideal Cp/Cv:	1.05		Total Back P % Set:	16.2	% Set
Relief Viscosity:	0.011	cP			



Equipment Data:

Equipment Tag:	V-1917	Type:	Pressure Vessel
Drawing:	D-2415-F24A	MAWP:	275 psig
Description:	Condensate Flash Tank	MAWT:	300 F

Scenario Input Data:

Length: ft

Diameter: in

Orientation:

Head Type:

Level Basis:

Additional Wetted Area: ft²

Level:

Bottom Elevation: ft

Area Exponent:

Adequate Drainage:

Insulation Factor:

Start Mass % Vapor:

Finish Mass % Vapor:

Remove Sensible Heat: Correct for Densities:

Set Pressure: psig

Allowable Overpressure:

Constant Back Pressure: psig

Use Thermodynamics:

Thermo Package:

Relief Device Kd:

Nozzle Sizing:

Outlet Pipe Sizing:

Scenario Output Data:

Wetted Area:	<input type="text" value="546.4"/>	ft ²
Fire Heat Input:	<input type="text" value="6.06"/>	MMBtu/hr
Total Heat/lb Vaporized:	<input type="text" value="232.0"/>	Btu/lb
Sensible Heat/lb Vaporized:	<input type="text" value="169.0"/>	Btu/lb
Latent Heat:	<input type="text" value="63.0"/>	Btu/lb
Initial Relief Temperature:	<input type="text" value="390"/>	F
Temp. at Start Quality:	<input type="text" value="390"/>	F
Cp at Start Quality:	<input type="text" value="0.830"/>	Btu/lb/F
Cp at Final Quality:	<input type="text" value="0.838"/>	Btu/lb/F
Liquid Density:	<input type="text" value="29.51"/>	lb/ft ³
Required Mass Rate:	<input type="text" value="82727.4"/>	lb/hr
Required Std. Vol. Rate:	<input type="text" value="10.17"/>	MMSCFD
Required Air Rate:	<input type="text" value="871191.7"/>	scfh air
Relief Mass Flux:	<input type="text" value="1262.8"/>	lb/sec/ft ²

Notes:



Equipment Data:

Equipment Tag:	V-1917	Type:	Pressure Vessel
Drawing:	D-2415-F24A	MAWP:	275 psig
Description:	Condensate Flash Tank	MAWT:	300 F


Liquid Stream Description: Valley Wells Condensate Flash Tank Liquid

Relief Stream Description: V-1917 Fire HC Vapor

Component	Liquid Stream Mole Fraction	Relief Stream Mole Fraction
carbon dioxide	0.0001	0.0004
nitrogen	0.0000	0.0000
methane	0.0050	0.0240
ethane	0.0158	0.0523
propane	0.0478	0.1161
isobutane	0.0250	0.0470
butane	0.0935	0.1613
isopentane	0.0619	0.0820
pentane	0.0883	0.1102
hexane	0.0466	0.0418
benzene	0.0354	0.0308
cyclohexane	0.0611	0.0467
2-methylhexane	0.0722	0.0515
3-methylhexane	0.0757	0.0528
heptane	0.0331	0.0216
octane	0.3385	0.1615

APPENDIX G – Fire Zone Plot Plan

Valley Wells
Fire Zone Map



NOTES:

REV.	DESCRIPTION
0	ISSUED FOR CONSTRUCTION
1	REVISED PER MOC-20210701-001

REVISIONS

REV.	DESCRIPTION	DATE	BY	CHK	DATE	APPR	DATE
1	REVISED PER MOC-20210701-001	10/6/21	AAC		10/6/21	RK	10/6/21
0	ISSUED FOR CONSTRUCTION	6/23/21	SAH		6/23/21		

ENGINEERING RECORD

DRAWN	CHECKED	DATE	SW	DATE	MECHANICAL	MECH
		06/04/14				
					PIPE	
					CON/STRUCT.	
					ELEC	
					INSTR/CONTROL	

OVERALL PLOT PLAN
SOUTHCROSS ENERGY
VALLEY WELLS TREATER

SCALE: N/A

PROJECT NO.: -

OFFICE: COTILLA, TX

DWG. NO.: 4029-20-101

REV: 1